
October 3, 2023

Ms. Misty Hailey
Westview C-6 School District
7441 Westview Road
Neosho, Missouri 64850

RE: Drinking Water Sampling – Westview School District
7441 Westview Road,
Neosho, Missouri 64850
Project Number: 923201

Ms. Hailey,

OCCU-TEC, Inc. (OCCU-TEC) is pleased to present the following report for drinking water sampling completed at Westview School District in Neosho, Missouri. The sampling was requested and approved by Ms. Misty Hailey of Westview School District. OCCU-TEC completed drinking water sampling of all potential drinking water sources, sources used in food preparation, cleaning, and utensil cleaning. Drinking water sampling was completed in accordance with the requirements set forth in Missouri Senate Bill #681/662 known as the “Get the Lead Out of School Drinking Water Act”.

METHODOLOGY

On August 10, 2023, Mr. Justin Arnold of OCCU-TEC completed testing of fourteen (14) sources throughout Westview District. Samples were collected as ‘First Draw’ samples after the fixtures had remained unused for a minimum period of 8 hours. Samples were collected in dedicated, laboratory-provided 250-milliliter plastic sample containers. Sample location information and photographic documentation are noted in the attached table.

Samples were shipped to Teklab, Inc. (Teklab) of Collinsville, Illinois for analysis using EPA method 200.8. Teklab is approved for sample analysis by the Missouri Department of Natural Resources (MDNR) under certification number 00930. A copy of the laboratory analytical results and Chain of Custody documentation are attached to this report.

RESULTS

Samples results were compared to the regulatory limit of 5 parts per billion (ppb) or micrograms per Liter (ug/L) outlined in Missouri Senate Bill 681/662. Of the samples collected, eight (8) of the thirty-two (32) contained lead concentrations at or above 5 ppb (ug/L). Below is a list of samples containing elevated concentrations of lead.

Sample ID	Location	Type	Result (ug/L)
201-WSD-02	Kitchen S Wall E Side	Sink	112
201-WSD-03	Kitchen S Wall W Side	Sink	11.5
201-WSD-04	Kitchen South Wall	Dish Sprayer	44.1
201-WSD-07	Room 122 N Wall	Sink	29.8
201-WSD-08	Room 111 Sink	Sink	12.1

LIMITATIONS

At the request of WNSD, classroom sinks, bathroom sinks and janitorial closet sinks were excluded from sampling. OCCU-TEC recommends placing signage on all sources not sampled during this assessment that indicate the source is not to be used for drinking water.

RECOMMENDATIONS

The following recommendations are in accordance with Senate Bill 681/662.

In accordance with the requirements set forth in Missouri Bill 681/662, fixtures exhibiting lead concentrations above 5 ppb (ug/L) must be remediated by replacement of lead-containing pipes, solder, fittings or fixtures with lead-free components, or the school shall install filtration at each point where water enters the building until such time as the source can be remediated. If installing a filter is not feasible, the school shall provide purified water at each outlet inventoried.

Additionally, any water coolers or drinking water outlets identified by the United States Environmental Protection Agency (EPA) as not being lead-free under the federal Lead Contamination Control Act of 1988 shall be replaced unless the unit has been tested and determined to have lead results under 5 ppb.

Within two weeks after receiving test results, the school shall make all testing results and any lead remediation plans available on the school's website. The school shall notify parents and staff via written notification within seven (7) business days

after receiving test results exceeding 5 ppb (ug/L). The notification shall include the following:

- Test results and a summary explaining the results.
- A description of any remedial steps taken.
- A description of the general health effects of lead contamination and community specific resources.
- Provide bottled water if there is not enough water to meet the drinking water needs of the students, teachers, and staff.

For fixtures exhibiting results above 5 ppb, follow up random “Flush” sampling shall be conducted annually on at least 25-percent of the remediated outlets until all outlets have been remediated. Drinking water sampling shall be conducted annually and annual drinking water test results shall be submitted by the district to the Department of Health and Senior Services (MDHSS).

SIGNATURE(S)

OCCU-TEC appreciates the opportunity to provide the above referenced consulting services to the WNSD. If you have any questions regarding the contents of this report, please contact us at (816) 231-5580.

Respectfully,



Kevin Heriford
Director EH&S Dept.





Brittany Dickmeyer
Safety Specialist


ATTACHMENTS

Outlet Inventory with Analytical Results Summary
Laboratory Analytical Results and COC Documentation


Drinking Water Assessment
Westview C-6 School District


ID:	201-WSD-01	Location:	Kitchen South Wall	
Photo:		Manufacturer:	FHP	
		Description:		
		Hand Washing Sink		
		Result:	4.1	ppb
		Date Sampled:	8/10/2023	By: JA
Recommended Action:				


ID:	201-WSD-02	Location:	Kitchen S Wall E Side	
Photo:		Manufacturer:	Zurn	
		Description:		
		Dish Washing Sink on east side. Sample had particles causing discoloration		
		Result:	112	ppb
		Date Sampled:	8/10/2023	By: JA
Recommended Action:		Replace Fixture/Unit and Resample		

ID:	201-WSD-03	Location:	Kitchen S Wall W Side	
Photo:		Manufacturer:	Zurn	
		Description:		
		Dish washing sink on west side		
		Result:	11.5	ppb
		Date Sampled:	8/10/2023	By: JA
Recommended Action:		Replace Fixture/Unit and Resample		


Drinking Water Assessment
Westview C-6 School District


ID:	201-WSD-04	Location:	Kitchen South Wall		
Photo:		Manufacturer:	T & S Brass Company		
		Description:			
		Dish Sprayer sink			
		Result:	44.1	ppb	
		Date Sampled:	8/10/2023	By:	JA
Recommended Action:		Replace Fixture/Unit and Resample			


ID:	201-WSD-05	Location:	Cafeteria West Wall		
Photo:		Manufacturer:	Halsey Taylor		
		Description:			
		Drinking Fountain Bottle Filler - both drinking fountain bubblers were removed from service.			
		Result:	<1.0	ppb	
		Date Sampled:	8/10/2023	By:	JA
Recommended Action:					

ID:	201-WSD-06	Location:	106 Break Room		
Photo:		Manufacturer:	Houzer		
		Description:			
		Sink			
		Result:	<1.0	ppb	
		Date Sampled:	8/10/2023	By:	JA
Recommended Action:					


Drinking Water Assessment
Westview C-6 School District

ID:	201-WSD-07	Location:	Room 122 N Wall		
Photo:		Manufacturer:	unknown		
		Description:			
		Sink in classroom			
		Result:	29.8	ppb	
		Date Sampled:	8/10/2023	By:	JA
Recommended Action:		Replace Fixture/Unit and Resample			


ID:	201-WSD-08	Location:	Room 111 Sink		
Photo:		Manufacturer:	B&K		
		Description:			
		Sink in classroom			
		Result:	12.1	ppb	
		Date Sampled:	8/10/2023	By:	JA
Recommended Action:		Replace Fixture/Unit and Resample			

ID:	201-WSD-09	Location:	Hall outside Gym		
Photo:		Manufacturer:	Elkay		
		Description:			
		Bottle filler on west side. Bubbler removed from service.			
		Result:	<1.0	ppb	
		Date Sampled:	8/10/2023	By:	JA
Recommended Action:					


Drinking Water Assessment
Westview C-6 School District


ID:	201-WSD-10	Location:	Hall outside Gym	
Photo:		Manufacturer:	Elkay	
		Description:		
		Bottle filler on East side. Bubbler removed from service.		
		Result:	<1.0	ppb
		Date Sampled:	8/10/2023	By: JA
Recommended Action:				

ID:	201-WSD-11	Location:	Concession Stand	
Photo:		Manufacturer:	Moen	
		Description:		
		Sink in concessions		
		Result:	<1.0	ppb
		Date Sampled:	8/10/2023	By: JA
Recommended Action:				

ID:	201-WSD-12	Location:	Art Room 117	
Photo:		Manufacturer:	Presenza	
		Description:		
		Sink in classroom		
		Result:	2.3	ppb
		Date Sampled:	8/10/2023	By: JA
Recommended Action:				

Drinking Water Assessment
Westview C-6 School District

ID:	201-WSD-13	Location:	Hall Outside 124		
Photo:		Manufacturer:	Elkay		
		Description:			
		Bottle filler on North side. Bubbler removed from service.			
		Result:	<1.0	ppb	
		Date Sampled:	8/10/2023	By:	JA
Recommended Action:					

ID:	201-WSD-14	Location:	Hall Outside 124		
Photo:		Manufacturer:	Elkay		
		Description:			
		Bottle filler on South side. Bubbler removed from service.			
		Result:	<1.0	ppb	
		Date Sampled:	8/10/2023	By:	JA
Recommended Action:					

September 25, 2023

Justin Arnold
Occu-Tec
2604 NE Industrial Drive
Suite 230
North Kansas, MO 64117
TEL: (816) 810-3276
FAX:



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: 923201 WSD

WorkOrder: 23081258

Dear Justin Arnold:

TEKLAB, INC received 14 samples on 8/16/2023 11:30:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley
Project Manager
(618)344-1004 ex 44
patrickriley@teklabinc.com

Client: Occu-Tec

Work Order: 23081258

Client Project: 923201 WSD

Report Date: 25-Sep-23

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	21
Chain of Custody	Appended

Client: Occu-Tec**Work Order:** 23081258**Client Project:** 923201 WSD**Report Date:** 25-Sep-23**Abbr Definition**

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Occu-Tec

Work Order: 23081258

Client Project: 923201 WSD

Report Date: 25-Sep-23

Qualifiers

- | | |
|---|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range |
| H - Holding times exceeded | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: Occu-Tec

Work Order: 23081258

Client Project: 923201 WSD

Report Date: 25-Sep-23

Cooler Receipt Temp: N/A °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: Occu-Tec**Work Order:** 23081258**Client Project:** 923201 WSD**Report Date:** 25-Sep-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec
Client Project: 923201 WSD
Lab ID: 23081258-001
Matrix: DRINKING WATER

Work Order: 23081258
Report Date: 25-Sep-23
Client Sample ID: 201-WSD-01
Collection Date: 08/10/2023 7:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.1	µg/L	5	09/23/2023 0:49	211167

Client: Occu-Tec
Client Project: 923201 WSD

Work Order: 23081258
Report Date: 25-Sep-23

Lab ID: 23081258-002

Client Sample ID: 201-WSD-02

Matrix: DRINKING WATER

Collection Date: 08/10/2023 7:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		112	µg/L	5	09/23/2023 0:52	211167



Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec
Client Project: 923201 WSD
Lab ID: 23081258-003
Matrix: DRINKING WATER

Work Order: 23081258
Report Date: 25-Sep-23
Client Sample ID: 201-WSD-03
Collection Date: 08/10/2023 7:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		11.5	µg/L	5	09/23/2023 0:56	211167

Client: Occu-Tec**Work Order:** 23081258**Client Project:** 923201 WSD**Report Date:** 25-Sep-23**Lab ID:** 23081258-004**Client Sample ID:** 201-WSD-04**Matrix:** DRINKING WATER**Collection Date:** 08/10/2023 7:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		44.1	µg/L	5	09/23/2023 1:00	211167



Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec
Client Project: 923201 WSD
Lab ID: 23081258-005
Matrix: DRINKING WATER

Work Order: 23081258
Report Date: 25-Sep-23
Client Sample ID: 201-WSD-05
Collection Date: 08/10/2023 7:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 2:30	211147

Client: Occu-Tec**Work Order:** 23081258**Client Project:** 923201 WSD**Report Date:** 25-Sep-23**Lab ID:** 23081258-006**Client Sample ID:** 201-WSD-06**Matrix:** DRINKING WATER**Collection Date:** 08/10/2023 7:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 2:33	211147



Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec
Client Project: 923201 WSD
Lab ID: 23081258-007
Matrix: DRINKING WATER

Work Order: 23081258
Report Date: 25-Sep-23
Client Sample ID: 201-WSD-07
Collection Date: 08/10/2023 7:27

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		29.8	µg/L	1	09/17/2023 2:37	211147



Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec
Client Project: 923201 WSD
Lab ID: 23081258-008
Matrix: DRINKING WATER

Work Order: 23081258
Report Date: 25-Sep-23
Client Sample ID: 201-WSD-08
Collection Date: 08/10/2023 7:29

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.1	µg/L	5	09/23/2023 1:22	211167



Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec
Client Project: 923201 WSD
Lab ID: 23081258-009
Matrix: DRINKING WATER

Work Order: 23081258
Report Date: 25-Sep-23
Client Sample ID: 201-WSD-09
Collection Date: 08/10/2023 7:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 3:02	211147



Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec
Client Project: 923201 WSD
Lab ID: 23081258-010
Matrix: DRINKING WATER

Work Order: 23081258
Report Date: 25-Sep-23
Client Sample ID: 201-WSD-10
Collection Date: 08/10/2023 7:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 2:41	211147



Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec
Client Project: 923201 WSD
Lab ID: 23081258-011
Matrix: DRINKING WATER

Work Order: 23081258
Report Date: 25-Sep-23
Client Sample ID: 201-WSD-11
Collection Date: 08/10/2023 7:39

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 3:06	211147



Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec
Client Project: 923201 WSD
Lab ID: 23081258-012
Matrix: DRINKING WATER

Work Order: 23081258
Report Date: 25-Sep-23
Client Sample ID: 201-WSD-12
Collection Date: 08/10/2023 7:39

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.3	µg/L	5	09/23/2023 1:25	211167



Laboratory Results

<http://www.teklabinc.com/>

Client: Occu-Tec
Client Project: 923201 WSD
Lab ID: 23081258-013
Matrix: DRINKING WATER

Work Order: 23081258
Report Date: 25-Sep-23
Client Sample ID: 201-WSD-13
Collection Date: 08/10/2023 7:43

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 3:09	211147

Client: Occu-Tec
Client Project: 923201 WSD
Lab ID: 23081258-014
Matrix: DRINKING WATER

Work Order: 23081258
Report Date: 25-Sep-23
Client Sample ID: 201-WSD-14
Collection Date: 08/10/2023 7:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/17/2023 3:13	211147

Client: Occu-Tec

Work Order: 23081258

Client Project: 923201 WSD

Report Date: 25-Sep-23

Carrier: Crossroads

Received By: MBP

Completed by:

On:

17-Aug-23

Amber Dilallo

Reviewed by:

On:

17-Aug-23

Ellie Hopkins

Pages to follow:

Chain of custody

2

Extra pages included

0

Shipping container/cooler in good condition?

 Yes ☒

 No ☐

 Not Present ☐

 Temp °C **N/A**

Type of thermal preservation?

 None ☒

 Ice ☐

 Blue Ice ☐

 Dry Ice ☐

Chain of custody present?

 Yes ☒

 No ☐

Chain of custody signed when relinquished and received?

 Yes ☒

 No ☐

Chain of custody agrees with sample labels?

 Yes ☒

 No ☐

Samples in proper container/bottle?

 Yes ☒

 No ☐

Sample containers intact?

 Yes ☒

 No ☐

Sufficient sample volume for indicated test?

 Yes ☒

 No ☐

All samples received within holding time?

 Yes ☒

 No ☐

Reported field parameters measured:

 Field ☐

 Lab ☐

 NA ☒

Container/Temp Blank temperature in compliance?

 Yes ☒

 No ☐

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?

 Yes ☐

 No ☐

 No VOA vials ☒

Water - TOX containers have zero headspace?

 Yes ☐

 No ☐

 No TOX containers ☒

Water - pH acceptable upon receipt?

 Yes ☒

 No ☐

 NA ☐

NPDES/CWA TCN interferences checked/treated in the field?

 Yes ☐

 No ☐

 NA ☒



Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory. - amberdilallo - 8/17/2023 9:19:52 AM

CHAIN OF CUSTODY

Pg 1 of 2 Workorder # 23081258

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: OCCU-TEC Inc. Address: 2604 NE Industrial Drive Suite 230 City/State/Zip: North Kansas City, MO 64117 Contact: Justin Arnold Phone: 816-810-3276 Email: jarnold@occutech.com Fax: 816-994-3478				Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input checked="" type="checkbox"/> NO ICE <u>N/A</u> °C Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <u>FOR LAB USE ONLY</u> LAB NOTES: Client Comments: <5ppb			
Are these samples known to be involved in litigation? If yes, a surcharge will apply: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are these samples known to be hazardous? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No							
PROJECT NAME/NUMBER 923201		SAMPLE COLLECTOR'S NAME Justin Arnold		# and Type of Containers		INDICATE ANALYSIS REQUESTED	
RESULTS REQUESTED		BILLING INSTRUCTIONS					
<input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)							
Lab Use Only	Sample ID	Date/Time Sampled	Matrix	UNP	HNO3	NaOH	H2SO4
23081258-001	201-WSD-01	8/10/2023 0715	Aqueous				
002	201-WSD-02	8/10/2023 0716	Aqueous				
003	201-WSD-03	8/10/2023 0717	Aqueous				
004	201-WSD-04	8/10/2023 0718	Aqueous				
005	201-WSD-05	8/10/2023 0722	Aqueous				
006	201-WSD-06	8/10/2023 0724	Aqueous				
007	201-WSD-07	8/10/2023 0727	Aqueous				
008	201-WSD-08	8/10/2023 0729	Aqueous				
009	201-WSD-09	8/10/2023 0731	Aqueous				
010	201-WSD-10	8/10/2023 0732	Aqueous				
011	201-WSD-11	8/10/2023 0739	Aqueous				
Relinquished By		Date/Time		Received By		Date/Time	
		8/15 1357				8/15/23 1357	
		8/15/23 1600				8/16/23 1130	

*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions

CHAIN OF CUSTODY

Pg 2 of 2 Workorder # 23081258

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

[illegible]

*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions