



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: ENVIRONMENTAL LEAD DETECTION (482)
Address: 436 Gardners Neck Rd
Swansea, MA 02777-3105

Order #: 533292

Matrix Drinking Water
Received 09/21/23
Reported 09/26/23


Attn:

Project: Melville Elementary School
Location: 1351 W Main Rd
Number: Portsmouth

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
533292-001	1W	West Wing Bottle Filler					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	09/22/23	SA
533292-002	2W	East Wing Bottle Filler					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	09/22/23	SA
533292-003	3W	Kitchen Faucet					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	09/22/23	SA

533292-09/26/23 12:55 PM


Reviewed By: **Ahmed Elnasseh**
Analyst

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	Rhode Island	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified
State	Certificate Number		
Rhode Island	ELAP LAO00084		
Virginia	VELAP 12299		

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results apply to the sample as received.