

NELAC NY 11769
NRPP 103216 AL
NRSB ARL0017
Rhode Island Certification # RAS 005 RMB 008

EPA Method #402-R-92-004
Liquid Scintillation
NRPP Device Code 8088
NRSB Device Code 12193

Laboratory Report for:

Property Tested: Project # 220748

ECM Inc.
181 Amaral Street
Riverside RI 02915

Portsmouth Middle School
125 Jepson Lane
Portsmouth RI 02871

Log Number	Device Number	Test Exposure Duration:				Area Tested	Result pCi/L
8318963	4907810	03/14/2023	10:20 am	03/16/2023	10:22 am	Main Office	< 0.4
8318964	4907820	03/14/2023	10:30 am	03/16/2023	10:31 am	Gym	< 0.4
8318965	4907837	03/14/2023	10:34 am	03/16/2023	10:34 am	A Wing Faculty Rm	< 0.4
8318966	4907847	03/14/2023	10:38 am	03/16/2023	10:39 am	B1.1 Lab	< 0.4
8318967	4907897	03/14/2023	10:38 am	03/16/2023	10:40 am	B1.1 Lab Duplicate	< 0.4
8318968	4907896	03/14/2023	10:40 am	03/16/2023	10:42 am	Art 3 C25	< 0.4
8318969	4907838	03/14/2023	10:43 am	03/16/2023	10:45 am	Technical Drawing	< 0.4
8318970	4907848	03/14/2023	10:45 am	03/16/2023	10:47 am	D Wing	0.5
8318971	4907828	03/14/2023	10:50 am	03/16/2023	10:51 am	Library	< 0.4
8318972	4907827	03/14/2023	10:53 am	03/16/2023	10:55 am	Theater	0.7
8318973	4907808	03/14/2023	10:22 am	03/16/2023	10:24 am	Field Blank	< 0.4


Comment: ECM-D. Simas was emailed a copy of this report.

Test Performed By: Placed: Jason Sweet RI00200 Retrieved: Jason Sweet RI00200

Distributed by: ECM-D. Simas

Date Received: 03/17/2023 Date Logged: 03/17/2023 Date Analyzed: 03/18/2023 Date Reported: 03/20/2023

This notice is provided to you by an organization or individual licensed and/or certified by the state of Rhode Island Department of Health to perform radon or radon progeny measurements or radon mitigation services as indicated by the RIDOH License #. Any questions, comments, or complaints regarding the person performing these measurements or mitigation services may be directed to Rhode Island Department of Health, Healthy Homes & Environment Team, Radon Program, 3 Capitol Hill Room 206, Providence, RI 02908-5097, doh.radon@health.ri.gov or (401) 222-7796.

Report Reviewed By: 

Report Approved By: 

Disclaimer:

Shawn Price, Director of Laboratory Operations, AccuStar Labs

The counting uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Laboratory personnel were not involved in the placement or retrieval of the samples. Analytical results relate to the samples as received by the laboratory. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.