



20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145/Email: info@envirovisionconsultants.com
NJ DOH IEHA Lic.# 1097

CLIENT: Norwood Public School District
PROJECT: Lead (Pb) in Water Sampling
ADDRESS: 177 Summit Street, Norwood, NJ 07648
FIELD TECHNICIANS: Dakota Arabia Meyer
REPORT DATE: September 4, 2025

Project Number 25-275
Norwood Public School

As per your request, EnviroVision Consultants, Inc. was contracted by Norwood Public School District to conduct Lead (Pb) in drinking water sampling at the Norwood Public School on August 26, 2025. The sample locations, in addition to a unique sample location code was determined/assigned by school district personnel. The school district performed the proper flushing of outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

Samples were analyzed at EMSL Analytical, Inc. in Cinnaminson, New Jersey *(NJDEP#03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

Four drinking water samples were collected and analyzed from the Norwood Public School. The samples were taken from two new fountains which also contained bottle fillers. A blank sample was submitted and analyzed, as required, for quality assurance purposes.

Results: All of the samples analyzed were "None Detected" and therefore less than the US EPA established threshold for lead in drinking water of 15 parts per billion (ppb or ug/L).

Should you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012533228**LIMS Reference ID:** AD33228**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Norwood Public School - 25-275

Project ID:

_Master Project-RAMA51

Customer PO:**Sales Rep:**

Sheryl Steinmetz

Received:

08/26/2025 19:10

Reported:

09/04/2025 09:38

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WF-15A/Fountain in APR near Nurses Lims Reference ID: AD33228-01 Matrix: Drinking Water Sampled: 08/26/25 07:35:00									
Metals									
Lead	ND	1	1.00		µg/L	09/02/25 14:30	09/03/25 14:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-15B/Bottle Filler APR near Nurses Lims Reference ID: AD33228-02 Matrix: Drinking Water Sampled: 08/26/25 07:35:00									
Metals									
Lead	ND	1	1.00		µg/L	09/02/25 14:30	09/03/25 14:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-14A/Fountain in 8th Grade Hallway near Room 43 Lims Reference ID: AD33228-03 Matrix: Drinking Water Sampled: 08/26/25 07:40:00									
Metals									
Lead	ND	1	1.00		µg/L	09/02/25 17:18	09/03/25 13:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WF-14B/Bottle Filler In 8th Grade Hallway near Room 43 Lims Reference ID: AD33228-04 Matrix: Drinking Water Sampled: 08/26/25 07:40:00									
Metals									
Lead	ND	1	1.00		µg/L	09/02/25 17:18	09/03/25 13:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Blank/Blank Lims Reference ID: AD33228-05 Matrix: Drinking Water Sampled: 08/26/25 07:45:00									
Metals									
Lead	ND	1	1.00		µg/L	09/02/25 17:18	09/03/25 13:19	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012533228**LIMS Reference ID:** AD33228**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Norwood Public School - 25-275

Project ID:

_Master Project-RAMA51

Customer PO:**Sales Rep:**

Sheryl Steinmetz

Received:

08/26/2025 19:10

Reported:

09/04/2025 09:38

Certified Analyses included in this Report

Analyte	Certifications
---------	----------------

EPA 200.8 in Drinking Water

Lead	NJDEP
------	-------

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2026
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2026
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2026
CTDPH	Connecticut Department of Public Health	PH-0270	06/30/2026
California ELAP	California Water Boards	1877	06/30/2026
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	04/01/2027
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012533228**LIMS Reference ID:** AD33228**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Norwood Public School - 25-275

Project ID:

_Master Project-RAMA51

Customer PO:**Sales Rep:**

Sheryl Steinmetz

Received:

08/26/2025 19:10

Reported:

09/04/2025 09:38

Notes and Definitions

Item	Definition
P2	Sample was preserved at the lab prior to analysis.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



20-21 Wagaraw Road - Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097

CLIENT:	Norwood Board of Education
PROJECT:	Norwood Public School
TECH:	Dakota Arabia-Meyer

ADDRESS:	177 Summit Street, Norwood, NJ 07648	PROJ #:	25-2
ADDRESS:	177 Summit Street, Norwood, NJ 07648	8 / 26 / 2025	
SAMPLING DATE:			

LEAD IN DRINKING WATER DATA SHEET

[illegible]

CHAIN OF CUSTODY

ANALYSIS:

_X_Unpreserved, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))

___ Preserved with HNO₃, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))

Matrix: Drinking Water, Sample Type: Grab

Sample(s) Temperature Upon Receipt (Lab Only):

Bottle Size: 250 mL, wide mouth

TURNAROUND TIME 4 Days

EMAIL RESULTS TO: info@envirovisionconsultants.com

**LABORATORY
SUBMITTED TO:**

LAB ORDER #

4NO₂ added @ 0150 on 8/28-10

PAGE _____ OF _____