

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results
MMES 52	9/25/2025 10:22	10/10/2025 13:34	70382149001	Lead	10.1
MMES 36	9/25/2025 10:26	10/10/2025 13:39	70382149002	Lead	3.7
MMES 108	9/25/2025 10:28	10/10/2025 13:43	70382149003	Lead	9.4
MMES 109	9/25/2025 10:30	10/10/2025 13:45	70382149004	Lead	6.9
MMES 98	9/25/2025 10:31	10/10/2025 13:49	70382149005	Lead	6.4
MMES 99	9/25/2025 10:32	10/10/2025 13:50	70382149006	Lead	6.6
MMES 92	9/25/2025 10:34	10/10/2025 13:52	70382149007	Lead	2.0
MMES 86	9/25/2025 10:36	10/10/2025 13:53	70382149008	Lead	4.1
MMES 83	9/25/2025 10:38	10/10/2025 13:55	70382149009	Lead	2.1
MMES 80	9/25/2025 10:40	10/10/2025 13:56	70382149010	Lead	8.5
MMES 69	9/25/2025 10:41	10/10/2025 13:58	70382149011	Lead	4.2
MMMS 3	9/25/2025 10:47	10/10/2025 13:59	70382149012	Lead	7.9
MMMS 93	9/25/2025 10:51	10/10/2025 14:01	70382149013	Lead	1.2
MMMS 22	9/25/2025 10:53	10/10/2025 14:02	70382149014	Lead	4.0
MMHS 3	9/25/2025 10:59	10/10/2025 14:07	70382149015	Lead	2.1
MMHS 4	9/25/2025 11:00	10/10/2025 14:08	70382149016	Lead	14.0
MMHS 6	9/25/2025 11:01	10/10/2025 14:10	70382149017	Lead	3.5
MMHS 1	9/25/2025 11:03	10/10/2025 14:11	70382149018	Lead	4.0
MMHS 13	9/25/2025 11:06	10/10/2025 14:13	70382149019	Lead	4.0
MMHS 24	9/25/2025 11:09	10/10/2025 14:14	70382149020	Lead	29.2

NYSDOH Action Level for Lead In Schools of 5 ppb

NYSDOH Action Level	Units
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L
5	ug/L