



BEDFORD AREA SCHOOL DISTRICT

February 27, 2024

Re: Engineering Economic Analysis--Geothermal vs. Conventional HVAC Systems for BHS
Renovation Project

An Engineering Economic Analysis was completed to compare the financial, operational, and environmental specifications of a Geothermal HVAC system versus a Conventional HVAC system. A brief summary shows Geothermal has higher upfront costs and potential energy savings. The Conventional system has lower upfront costs and higher energy costs. We encourage community members to review the report to gain industry-provided knowledge of this particular topic.

ENGINEERING ECONOMIC ANALYSIS HVAC SYSTEMS - SUMMARY REPORT

for the

BEDFORD AREA SCHOOL DISTRICT

BEDFORD, PENNSYLVANIA



Comparison of a Geothermal Heat Pump System Versus Traditional Boiler/Chiller/Tower System



Prepared by Gatter & Diehl, Inc
Consulting Engineers

Office Locations:

5 Corporate Drive, Bedford, PA 15554

100 Winding Creek Boulevard, Mechanicsburg PA 17050

Ph: 717-657-9700

WWW.GATTERDIEHL.COM

Published: February 22, 2024

INTRODUCTION:

The primary purpose of this report is to demonstrate the engineering economic comparison of a Geothermal Heat Pump System in contrast to that of a traditional Boiler/Chiller/Tower HVAC system, for the Bedford High School 2024 project.

Information is also provided herein relative to operational and environmental advantages/disadvantages of each system type.

To perform an economic analysis, a direct comparison must be made with sound engineering judgement and consideration to relative capital costs, energy costs, plus maintenance and repair costs.

CAPITAL COST DATA:

Capital costs used within this report, to arrive at the upfront systems equipment and installation cost differentials, were derived by sourcing costs for each system from contractors, vendors and construction management firms. All contractors and vendors used in sourcing these costs are familiar with the District, have provided services to the District, and are familiar with current planning. As an additional check, to substantiate the order-of-magnitude of the added construction cost associated with implementing a Geothermal HVAC system versus a traditional Boiler/Chiller/Tower system, a 3rd party construction firm was engaged to provide cursory review of the cost differential. For this study, an added construction cost for a Geothermal system was determined to be \$707,000. This value is conservatively high, so as not to favor Geothermal.

TOTAL OPERATING COSTS

Two operating cost perspectives were performed within the analysis as follows:

Analysis 1 – District Records Basis

Use of actual utility costs, preventative maintenance, repair records and available data were sourced from District records to arrive at Total Operating Cost of the systems.

Analysis 2 – Energy Model & District Records Basis

Use of Energy Modeling Software to model energy consumption, combined with District records were sourced to arrive at Total Operating Cost of the systems.

EXISTING SYSTEMS - HIGH SCHOOL AND MIDDLE SCHOOL

Note, the existing High School primarily uses a boiler chiller-tower HVAC system for heating and cooling, while the existing Middle School primarily uses a geothermal heat pump system for heating and cooling.

RECORD DATA – USED FOR BOTH ANALYSIS 1 AND 2:

The district shared the preventative maintenance, repairs and utility cost record data including electric, gas and water for the most recent two years, for both the High School and Middle School. Information from both schools have been integrated into the engineering analysis contained within this report.

ENERGY MODELING SOFTWARE FOR ANALYSIS 2:

Software utilized was Trane Trace 700v6.3.5. This software is recognized by the IRS, DOE, ASHRAE, USGBC and other organizations as meeting the rigors of compliance for both energy and financial calculations. This software uses 8760 hour-by-hour simulation, using NOAA hourly weather data.

KNOWN AND GIVEN:

- Baseline conditioned space analysis: 160,000 SF
- High School average electric cost/kwhr: 11.5 cents
- High School average NG cost/therm: \$1.04
- High School average water cost/gallon: \$.029472/gallon
- Location: Bedford, Pennsylvania
- Annual PM & repair costs: Sourced from District Records
- Annual energy consumption costs:
 - Analysis 1 - uses District sourced record data only
 - Analysis 2 - uses District sourced record data combined with Modeling Software analysis.

BUILDING SQUARE FOOT DATA:

Where overall building square footage differentials occur between the existing Middle School (Geothermal) and the existing High School (Boiler/Chiller/Tower), actual district record-data was utilized to account for the variances in order to arrive at an engineering basis of equality. Likewise, where heating and cooling square footages differ between the existing High School and existing Middle School, actual district record data was utilized to account for the variances in order to arrive at an engineering basis of equality.

PAYBACK CALCULATIONS:

In this report, two forms of payback/ROI are utilized as follows:

1) Simple Payback Method:

This method does not consider the “time value of money”. It is simply a factor of initial costs divided by annual savings to arrive at a payback period (years). In general, this method should only be considered prudently applied whenever a project or investment provides a very rapid rate of return. Generally, this method becomes exceedingly less prudent as a decision-making factor anytime the resulting payback approaches 9 years. Simple payback in this report is only used to quickly identify a project’s financial standing, prior to performing a “time value of money calculation”.

1) Net Present Value (NPV) Method:

$$NPV = \sum_{t=0}^N \frac{NCF_t}{(1+i_t)^t} \quad [+RV]$$

As a commonly known principle of finance, money in hand now is more valuable than money received years later. Thus, future money is less valuable than current money because time erodes buying power, hence the term “time value of money”. In this case, to compare the value of money now with the value of future money, NPV calculations in concert with the value of expected cash savings were applied and tabulated herein. Knowing NPV predictions of return on initial investment, time period and discount rate serves to facilitate the basis for prudent financial decision-making.

ANALYSIS 1 – District Records Based

BEDFORD - HIGH SCHOOL

HVAC System Comparisons



2/22/2024

GATTER & DIEHL, Inc.

Option #	HVAC System Types	Comparative Added Construction Cost	Annual Energy Cost	Annual PM & Repair Cost	Total Annual Operating Cost	Simple Payback Years
Option 1	Chiller/Boiler/Tower	Base System	\$ 181,822	\$ 66,129	\$ 247,951	Base System
Option 2	WSHP - Geothermal	\$707,000	\$ 122,497	\$ 20,840	\$ 143,337	6.8
Notes:		Annual \$ Savings	\$ 59,325	\$ 45,289	\$ 104,614	

All system options used the same data, building attributes, operational characteristics, ASHRAE standards, etc.

PM = Preventative Maintenance

Chiller/Boiler/Tower - Total Operating Cost /SF = \$1.55

Geothermal - Total Operating Cost/SF = 90 cents

$$NPV = \sum_{t=0}^N \frac{NCF_t}{(1+i_t)^t} \quad [+RV]$$

ANALYSIS 1											
NPV - Years 1-50 at Various Discount Rates											
Rate =	4.10%		Rate =	5.00%		Rate =	7.00%		Rate =	9.00%	
Year	Value		Year	Value		Year	Value		Year	Value	
0	-707,000		0	-707,000		0	-707,000		0	-707,000	
1	\$104,614		1	\$104,614		1	\$104,614		1	\$104,614	
2	\$104,614		2	\$104,614		2	\$104,614		2	\$104,614	
3	\$104,614		3	\$104,614		3	\$104,614		3	\$104,614	
4	\$104,614		4	\$104,614		4	\$104,614		4	\$104,614	
5	\$104,614		5	\$104,614		5	\$104,614		5	\$104,614	
6	\$104,614		6	\$104,614		6	\$104,614		6	\$104,614	
7	\$104,614		7	\$104,614		7	\$104,614		7	\$104,614	
8	\$104,614		8	\$104,614		8	\$104,614		8	\$104,614	
9	\$104,614		9	\$104,614		9	\$104,614		9	\$104,614	
10	\$104,614		10	\$104,614		10	\$104,614		10	\$104,614	
11	\$104,614		11	\$104,614		11	\$104,614		11	\$104,614	
12	\$104,614		12	\$104,614		12	\$104,614		12	\$104,614	
13	\$104,614		13	\$104,614		13	\$104,614		13	\$104,614	
14	\$104,614		14	\$104,614		14	\$104,614		14	\$104,614	
15	\$104,614		15	\$104,614		15	\$104,614		15	\$104,614	
16	\$104,614		16	\$104,614		16	\$104,614		16	\$104,614	
17	\$104,614		17	\$104,614		17	\$104,614		17	\$104,614	
18	\$104,614		18	\$104,614		18	\$104,614		18	\$104,614	
19	\$104,614		19	\$104,614		19	\$104,614		19	\$104,614	
20	\$104,614		20	\$104,614		20	\$104,614		20	\$104,614	
21	\$104,614		21	\$104,614		21	\$104,614		21	\$104,614	
22	\$104,614		22	\$104,614		22	\$104,614		22	\$104,614	
23	\$104,614		23	\$104,614		23	\$104,614		23	\$104,614	
24	\$104,614		24	\$104,614		24	\$104,614		24	\$104,614	
25	\$104,614		25	\$104,614		25	\$104,614		25	\$104,614	
NPV 1-25 yrs = \$910,150			NPV 1-25 yrs = \$767,424			NPV 1-25 yrs = \$512,128			NPV 1-25 yrs = \$320,579		
26	\$104,614		26	\$104,614		26	\$104,614		26	\$104,614	
27	\$104,614		27	\$104,614		27	\$104,614		27	\$104,614	
28	\$104,614		28	\$104,614		28	\$104,614		28	\$104,614	
29	\$104,614		29	\$104,614		29	\$104,614		29	\$104,614	
30	\$104,614		30	\$104,614		30	\$104,614		30	\$104,614	
31	\$104,614		31	\$104,614		31	\$104,614		31	\$104,614	
32	\$104,614		32	\$104,614		32	\$104,614		32	\$104,614	
33	\$104,614		33	\$104,614		33	\$104,614		33	\$104,614	
34	\$104,614		34	\$104,614		34	\$104,614		34	\$104,614	
35	\$104,614		35	\$104,614		35	\$104,614		35	\$104,614	
36	\$104,614		36	\$104,614		36	\$104,614		36	\$104,614	
37	\$104,614		37	\$104,614		37	\$104,614		37	\$104,614	
38	\$104,614		38	\$104,614		38	\$104,614		38	\$104,614	
39	\$104,614		39	\$104,614		39	\$104,614		39	\$104,614	
40	\$104,614		40	\$104,614		40	\$104,614		40	\$104,614	
41	\$104,614		41	\$104,614		41	\$104,614		41	\$104,614	
42	\$104,614		42	\$104,614		42	\$104,614		42	\$104,614	
43	\$104,614		43	\$104,614		43	\$104,614		43	\$104,614	
44	\$104,614		44	\$104,614		44	\$104,614		44	\$104,614	
45	\$104,614		45	\$104,614		45	\$104,614		45	\$104,614	
46	\$104,614		46	\$104,614		46	\$104,614		46	\$104,614	
47	\$104,614		47	\$104,614		47	\$104,614		47	\$104,614	
48	\$104,614		48	\$104,614		48	\$104,614		48	\$104,614	
49	\$104,614		49	\$104,614		49	\$104,614		49	\$104,614	
50	\$104,614		50	\$104,614		50	\$104,614		50	\$104,614	
NPV 1- 50 yrs = \$2,209,369			NPV 1- 50 yrs = \$1,909,825			NPV 1- 50 yrs = \$1,443,751			NPV 1- 50 yrs = \$1,146,745		
NPV 1- 50 yrs = \$746,176											
Not included above: Future long term avoided capital costs, unique to Geothermal Systems											
1. Years 15 - 20: Tower Replacement added cost \$200,000											
2. Years 26 - 30: Chiller/Boiler System added cost \$900,000 (because Geothermal borefields last 50+ years, thus no Boilers, Chillers or Tower would exist to be replaced)											

Added First Cost - Geothermal

But yields Savings

Continued Savings of Geothermal

ANALYSIS 2 – Energy Model and District Records Based

BEDFORD - HIGH SCHOOL HVAC System Comparisions



2/22/2024

GATTER & DIEHL, Inc.

Option #	HVAC System Types	Comparative Added Construction Cost	Annual Energy Cost	Annual PM & Repair Cost	Total Annual Operating Cost	Simple Payback Years
Option 1	Chiller/Boiler/Tower	Base System	\$ 181,599	\$ 66,129	\$ 247,728	Base System
Option 2	WSHP - Geothermal	\$707,000	\$ 104,493	\$ 20,840	\$ 125,333	5.8
Notes:		Annual \$ Savings	\$ 77,106	\$ 45,289	\$ 122,395	

All system options used the same data, building attributes, operational characteristics, ASHRAE standards, etc.

PM = Preventative Maintenance

Chiller/Boiler/Tower - Total Operating Cost /SF = \$1.55

Geothermal - Total Operating Cost/SF = 78 cents

$$NPV = \sum_{t=0}^N \frac{NCF_t}{(1+i_t)^t} \quad [+RV]$$

ANALYSIS 2											
NPV - Years 1-50 at Various Discount Rates											
Rate = 4.10%		Rate = 5.00%		Rate = 7.00%		Rate = 9.00%		Rate = 14.00%			
Year	Value	Year	Value	Year	Value	Year	Value	Year	Value		
0	-\$707,000	0	-\$707,000	0	-\$707,000	0	-\$707,000	0	-\$707,000	<div style="position: relative; height: 100px;"> Added First Cost - Geothermal But yields Savings </div>	
1	\$122,395	1	\$122,395	1	\$122,395	1	\$122,395	1	\$122,395		
2	\$122,395	2	\$122,395	2	\$122,395	2	\$122,395	2	\$122,395		
3	\$122,395	3	\$122,395	3	\$122,395	3	\$122,395	3	\$122,395		
4	\$122,395	4	\$122,395	4	\$122,395	4	\$122,395	4	\$122,395		
5	\$122,395	5	\$122,395	5	\$122,395	5	\$122,395	5	\$122,395		
6	\$122,395	6	\$122,395	6	\$122,395	6	\$122,395	6	\$122,395		
7	\$122,395	7	\$122,395	7	\$122,395	7	\$122,395	7	\$122,395		
8	\$122,395	8	\$122,395	8	\$122,395	8	\$122,395	8	\$122,395		
9	\$122,395	9	\$122,395	9	\$122,395	9	\$122,395	9	\$122,395		
10	\$122,395	10	\$122,395	10	\$122,395	10	\$122,395	10	\$122,395		
11	\$122,395	11	\$122,395	11	\$122,395	11	\$122,395	11	\$122,395		
12	\$122,395	12	\$122,395	12	\$122,395	12	\$122,395	12	\$122,395		
13	\$122,395	13	\$122,395	13	\$122,395	13	\$122,395	13	\$122,395		
14	\$122,395	14	\$122,395	14	\$122,395	14	\$122,395	14	\$122,395		
15	\$122,395	15	\$122,395	15	\$122,395	15	\$122,395	15	\$122,395		
16	\$122,395	16	\$122,395	16	\$122,395	16	\$122,395	16	\$122,395		
17	\$122,395	17	\$122,395	17	\$122,395	17	\$122,395	17	\$122,395		
18	\$122,395	18	\$122,395	18	\$122,395	18	\$122,395	18	\$122,395		
19	\$122,395	19	\$122,395	19	\$122,395	19	\$122,395	19	\$122,395		
20	\$122,395	20	\$122,395	20	\$122,395	20	\$122,395	20	\$122,395		
21	\$122,395	21	\$122,395	21	\$122,395	21	\$122,395	21	\$122,395		
22	\$122,395	22	\$122,395	22	\$122,395	22	\$122,395	22	\$122,395		
23	\$122,395	23	\$122,395	23	\$122,395	23	\$122,395	23	\$122,395		
24	\$122,395	24	\$122,395	24	\$122,395	24	\$122,395	24	\$122,395		
25	\$122,395	25	\$122,395	25	\$122,395	25	\$122,395	25	\$122,395		
NPV 1-25 yrs = \$1,185,014		NPV 1-25 yrs = \$1,018,028		NPV 1-25 yrs = \$719,340		NPV 1-25 yrs = \$495,235		NPV 1-25 yrs = \$134,212		<div style="position: relative; height: 100px;"> Continued Savings of Geothermal </div>	
26	\$122,395	26	\$122,395	26	\$122,395	26	\$122,395	26	\$122,395		
27	\$122,395	27	\$122,395	27	\$122,395	27	\$122,395	27	\$122,395		
28	\$122,395	28	\$122,395	28	\$122,395	28	\$122,395	28	\$122,395		
29	\$122,395	29	\$122,395	29	\$122,395	29	\$122,395	29	\$122,395		
30	\$122,395	30	\$122,395	30	\$122,395	30	\$122,395	30	\$122,395		
31	\$122,395	31	\$122,395	31	\$122,395	31	\$122,395	31	\$122,395		
32	\$122,395	32	\$122,395	32	\$122,395	32	\$122,395	32	\$122,395		
33	\$122,395	33	\$122,395	33	\$122,395	33	\$122,395	33	\$122,395		
34	\$122,395	34	\$122,395	34	\$122,395	34	\$122,395	34	\$122,395		
35	\$122,395	35	\$122,395	35	\$122,395	35	\$122,395	35	\$122,395		
36	\$122,395	36	\$122,395	36	\$122,395	36	\$122,395	36	\$122,395		
37	\$122,395	37	\$122,395	37	\$122,395	37	\$122,395	37	\$122,395		
38	\$122,395	38	\$122,395	38	\$122,395	38	\$122,395	38	\$122,395		
39	\$122,395	39	\$122,395	39	\$122,395	39	\$122,395	39	\$122,395		
40	\$122,395	40	\$122,395	40	\$122,395	40	\$122,395	40	\$122,395		
41	\$122,395	41	\$122,395	41	\$122,395	41	\$122,395	41	\$122,395		
42	\$122,395	42	\$122,395	42	\$122,395	42	\$122,395	42	\$122,395		
43	\$122,395	43	\$122,395	43	\$122,395	43	\$122,395	43	\$122,395		
44	\$122,395	44	\$122,395	44	\$122,395	44	\$122,395	44	\$122,395		
45	\$122,395	45	\$122,395	45	\$122,395	45	\$122,395	45	\$122,395		
46	\$122,395	46	\$122,395	46	\$122,395	46	\$122,395	46	\$122,395		
47	\$122,395	47	\$122,395	47	\$122,395	47	\$122,395	47	\$122,395		
48	\$122,395	48	\$122,395	48	\$122,395	48	\$122,395	48	\$122,395		
49	\$122,395	49	\$122,395	49	\$122,395	49	\$122,395	49	\$122,395		
50	\$122,395	50	\$122,395	50	\$122,395	50	\$122,395	50	\$122,395		
NPV 1- 50 yrs = \$2,584,891		NPV 1- 50 yrs = \$2,234,434		NPV 1- 50 yrs = \$1,689,142		NPV 1- 50 yrs = \$1,341,655		NPV 1- 50 yrs = \$873,001			


Not included above: Future long term avoided capital costs, unique to Geothermal Systems

1. Years 15 - 20: Tower Replacement added cost \$200,000

2. Years 26 - 30: Chiller/Boiler System added cost \$900,000 (because Geothermal borefields last 50+ years, thus no Boilers, Chillers or Tower would exist to be replaced)

OPERATIONAL & ENVIRONMENTAL

The following Operational and Environmental characteristics should be considered as a part of a final decision-making process.

BEDFORD - HIGH SCHOOL HVAC System Comparisons				GATTER & DIEHL, Inc.			2/22/2024				
Analysis	HVAC System Types	Typical Exchanger Life Expectancy	Backup Heat Required	Weather Independence	Aesthetically Friendly?	Legionella Concerns/Treatment Required?	Site noise/Interior Noise	Winterization Needed?	Emissions Site NOx	Humidity Reduction Control	Reliability
1	Chiller/Boiler/Tower	14-16 years	No	Very good	Cooling Tower 17' tall	Yes/Yes	Max site /moderate interior	Yes	Yes	Yes - requires additional coil	Good
2	WSHP - Geothermal	50+ years	No	Very good	No visual detriments	No/No	No site noise/low interior	No	None	Yes - Inherent	Better

SUMMARY AND RECOMMENDATIONS

The results of the Engineering Economic Analysis demonstrate that a Geothermal HVAC system is a prudent financial use of funds for the district, as proven by its rapid Simple Payback and Net Present Value ROI at various rates of return, up to and including double-digit discount rates far in excess of 10%. Similar studies by state, federal, university, independent and industry organizations have yielded the very same conclusions with respect to energy efficiency, financial investment, environmental quality and long-term sustainability.

Note that future capital replacement costs, financially detrimental to the use of the Chiller/Boiler/Tower system, were intentionally left out of this analysis. Those costs being the avoided replacement costs of the Tower Heat Exchanger in the first 25 years, and the capital costs beyond 25 years whereby Chiller/Boiler/Tower upgrades require capital expenditures far exceeding Geothermal, given that Geothermal heat exchangers last 50+ years. Throughout the analysis process, the Chiller/Boiler/Tower scenario has received all of the cost-benefits. Hence, the actual ROI expected over the entire life cycle of the Geothermal system could very reasonably exceed the values shown in this report, all while providing real tangible operational and environmental benefits to the district.

It's also worth noting that Geothermal lends itself to satisfy eligibility for clean energy grant programs when such plans are open and available for application, while Boiler/Chiller/Tower systems do not.