

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

## CERTIFICATE OF ANALYSIS

**Laura Tallia**  
**West Milford BOE**  
**46 Highlander Drive**  
**West Milford, NJ 07480**

Project Name and Number: **WM HS - DOE Lead 1st Draw + Flush / WM High School**  
Workorder: **25F2124**  
Purchase Order:

July 15, 2025

This report relates only to the sample(s) as received by the laboratory on June 18, 2025. Laboratory reports may not be reproduced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Caution is advised for the utilization of preliminary data included in reports labeled as "Preliminary Report" and should not be used for regulatory purposes. A laboratory signature is provided on final reports only.

If you have any questions in reference to this laboratory report, please contact your Pace Analytical Services, LLC-Fairfield project coordinator.

Note: This cover page is included as part of the Analytical Report and must be retained as a permanent record thereof.



Victor G. Cervantes, Project Manager

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-01

**Matrix:** Drinking Water

**Date Collected:** 06/17/2025 03:30

**Sample ID:** Field Blank

**Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 06:17	07/11/2025 06:17	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-02 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 03:40  
**Sample ID:** Loading Dock Hose Bib (1) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 03:32	07/11/2025 03:32	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-03 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 03:47  
**Sample ID:** Loading Dock right ice machine (2) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 06:22	07/11/2025 06:22	1



Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-04 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 03:50  
**Sample ID:** Loading Dock left ice Machine (3) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 06:27	07/11/2025 06:27	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-05 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 04:02  
**Sample ID:** Boys Locker Rm. Hallway Left Bottle Fill (4) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 06:33	07/11/2025 06:33	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-06 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 04:04  
**Sample ID:** Boys Locker Rm. Hallway Right Bottle Fill (5) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 06:38	07/11/2025 06:38	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-07 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 04:09  
**Sample ID:** Kit 2 Bay Single Sink (6) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 06:43	07/11/2025 06:43	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-08  
**Sample ID:** Kit Prep Sink (7) (DS)

**Matrix:** Drinking Water

**Date Collected:** 06/17/2025 04:12

**Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00241		mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 06:48	07/11/2025 06:48	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-09 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 04:23  
**Sample ID:** Kit 3 Bay Right Sink (8) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00374		mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 06:54	07/11/2025 06:54	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-10 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 04:27  
**Sample ID:** Kit 3 Bay Left Sink (9) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 06:59	07/11/2025 06:59	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-11 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 04:30  
**Sample ID:** Kit Single Middle Sink (10) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00324		mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 07:15	07/11/2025 07:15	1



Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-12 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 04:35  
**Sample ID:** Kit 2 Bay by Office Sink (11) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00480		mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 07:20	07/11/2025 07:20	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-13 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 04:39  
**Sample ID:** Faculty Room Sink (12) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 07:26	07/11/2025 07:26	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-14 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 04:45  
**Sample ID:** Rm C-8 Fountain (13) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00323		mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 07:31	07/11/2025 07:31	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-15 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 04:54  
**Sample ID:** Nurses Office Sink (14) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 07:36	07/11/2025 07:36	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-16 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 04:59  
**Sample ID:** Business Wing Bottle Fill (15) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 07:42	07/11/2025 07:42	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-17 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 05:01  
**Sample ID:** Business Wing Fountain (16) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 07:47	07/11/2025 07:47	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-18 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 05:05  
**Sample ID:** Rm. 100 Sink (17) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00509		mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 07:52	07/11/2025 07:52	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-19 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 05:11  
**Sample ID:** Rm. 142 Home Ec Sink (18) G-10 (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00327		mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 07:57	07/11/2025 07:57	1



Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-20 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 05:15  
**Sample ID:** Rm. 142 Home Ec Sink (19) G-11 (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/14/2025 19:20	07/14/2025 19:20	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-21 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 05:19  
**Sample ID:** Rm. 142 Home Ec Sink (20) G-12 (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 04:04	07/11/2025 04:04	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-22 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 05:22  
**Sample ID:** Rm. 142 Home Ec Sink (21) G-13 (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 08:24	07/11/2025 08:24	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-23 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 05:26  
**Sample ID:** Rm. 142 Home Ec Sink (22) G-14 (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 08:29	07/11/2025 08:29	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-24 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 05:29  
**Sample ID:** Rm. 142 Home Ec Sink (23) G-15 (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00693		mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 08:46	07/11/2025 08:46	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-25 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 05:33  
**Sample ID:** Auditorium left bottle fill (24) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 08:51	07/11/2025 08:51	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-26 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 05:36  
**Sample ID:** Auditorium right bottle fill (25) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 08:57	07/11/2025 08:57	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-27 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 05:39  
**Sample ID:** English Wing Bottle Fill (26) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 09:02	07/11/2025 09:02	1



Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-28  
**Sample ID:** Rm. 137 Sink (32) (DS)

**Matrix:** Drinking Water

**Date Collected:** 06/17/2025 05:41  
**Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 09:07	07/11/2025 09:07	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-29 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 05:51  
**Sample ID:** Science Wing Bottle Fill (28) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 09:13	07/11/2025 09:13	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-30 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 05:53  
**Sample ID:** Science Wing Fountain ((29) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 09:22	07/11/2025 09:22	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-31 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 06:00  
**Sample ID:** Math Wing Bottle Fill (30) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 09:27	07/11/2025 09:27	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-32 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 06:02  
**Sample ID:** Math Wing Fountain (31) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	ND	U	mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 09:43	07/11/2025 09:43	1

Pace Analytical Services, LLC-Fairfield  
1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004  
(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)

**Lab ID:** 25F2124-33 **Matrix:** Drinking Water **Date Collected:** 06/17/2025 06:11  
**Sample ID:** Upper Library Ofc Sink (32) (DS) **Date Received:** 06/18/2025 15:20

**Total Metals - Pace Analytical Services, LLC-Fairfield**

Analyte	Results	Flag	Units	MDL	RDL	Method	Prepared	Analyzed	Dilution
Lead	0.00691		mg/L	0.000492	0.00200	EPA 200.8	07/11/2025 09:48	07/11/2025 09:48	1

**Pace Analytical Services, LLC-Fairfield**  
**1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004**  
**(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)**

### Qualifiers

U Compound not detected

---

### Abbreviations

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the Reporting Detection Limit (RDL)
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
<	Less than reporting limit
≤	Less than or equal to reporting limit
>	Greater than reporting limit
≥	Greater than or equal to reporting limit
MDL	Method Detection Limit
RDL	Reporting Detection Limit
MCL/AL	Maximum Contaminant Level/Action Level
mg/kg wet	Results reported as wet weight
TTLC	Total Threshold Limit Concentration
STLC	Soluble Threshold Limit Concentration
TCLP	Toxicity Characteristic Leachate Procedure

**Pace Analytical Services, LLC-Fairfield**  
**1275 Bloomfield Ave, Ste 37D, Fairfield, NJ 07004**  
**(P) (973) 227-0422 - [www.pacelabs.com](http://www.pacelabs.com)**

**Laboratory Certification List for this report.**

Laboratory	Certification				
	NJ	NY	PA	CT	
Pace Analytical Services, LLC Ewing 812 Silvia Street Ewing, NJ 08628	11005	12046	68-05417		
Pace Analytical Services, LLC-Fairfield 1275 Bloomfield Ave, Ste 37D Fairfield, NJ 07004	07010	11634	68-02903		





Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

# CHAIN OF CUSTODY



**25F2124**

Page 1 of 13

West Milford BOE  
WM HS - DOE Lead 1st Draw + Flush / W/

**Client:** West Milford BOE

46 Highlander Drive West Milford, NJ 07480

**Project:** West Milford High School: WM HS - DOE Lead 1st Draw + Flush

**Project Mgr:** Laura Tallia

(p) 973-697-1700, (c)

**Project #:** WM High School

**PO #:**

**Comments:**

\*\*1st Draw - Water Stagnation min. 8 hrs\*\*

16 Nosenzo Pond Rd, West Milford, NJ 07480

## Turn Around Time

☐ Standard 2 Weeks

**Rush (Choose One Below) \*\***

☐ 24 Hr. ☐ 72 Hr.

☐ 48 Hr. ☐ 1 Week

☐ Other (provide Date/Time)

Date: \_\_\_\_\_ Time: \_\_\_\_\_

\*\* May Need Lab Approval

## Report / Electronic Format

☐ Results Only/Lvl 2 ☐ Email Delivery

☐ NJ DEP Reduced ☐ Hazsite EDD

☐ NJ DEP Full ☐ EQUIS EDD

☐ State Forms/E2 ☐ Excel

PWSID # 1615326 SRP # \_\_\_\_\_

Lab ID	Sample Source: Field ID	Sampled Date Time	SampleType	Matrix	Analysis Requested	Field Analysis	Time	Measurement
25F2124-01	Field Blank	6/17 3:30 AM	Field Blank	DW	ICP-MS Lead			
						Container	Qty	1
						250mL Plastic HNO3	1	
-02	Loading Dock Hose Bib (1)	6-17-25 3:40 AM	Grab	DW	ICP-MS Lead			
						Container	Qty	1
						250mL Plastic HNO3	1	
DS								
-03	Loading Dock right ice machine (2)	6-17-25 3:47 AM	Grab	DW	ICP-MS Lead			
						Container	Qty	1
						250mL Plastic HNO3	1	
DS								

Released By

*Damian Fitzgerald*

Date / Time

6/17/25 7:30 AM

Received By

*Don D Pace*

*Pace*

Date / Time

6/18/25 1220

Released By

*Don D Pace*

Date / Time

6/18/25 1520

Received By

*P. D. Adams*

Date / Time

6/19/25 11:23 4.2



Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Page 2 of 13

Lab ID	Sample Source: Field ID	Sampled		Sample Type	Matrix	Analysis Requested	Field Analysis						
		Date	Time				Time	Measurement					
-04	Loading Dock left Ice Machine (3)	6/17	3:50 AM	Grab	DW	ICP-MS Lead							
							<table border="1"><tr><td>Container</td><td>Qty</td><td>1</td></tr><tr><td>250mL Plastic HNO3</td><td>1</td><td></td></tr></table>	Container	Qty	1	250mL Plastic HNO3	1	
Container	Qty	1											
250mL Plastic HNO3	1												
DS													
-05	Boys Locker Rm. Hallway Left Bottle Fill (4)	6/17	4:02 AM	Grab	DW	ICP-MS Lead							
							<table border="1"><tr><td>Container</td><td>Qty</td><td>1</td></tr><tr><td>250mL Plastic HNO3</td><td>1</td><td></td></tr></table>	Container	Qty	1	250mL Plastic HNO3	1	
Container	Qty	1											
250mL Plastic HNO3	1												
DS													
-06	Boys locker rm. Hallway right bottle fill (5)	6/17	4:04 AM	Grab	DW	ICP-MS Lead							
							<table border="1"><tr><td>Container</td><td>Qty</td><td>1</td></tr><tr><td>250mL Plastic HNO3</td><td>1</td><td></td></tr></table>	Container	Qty	1	250mL Plastic HNO3	1	
Container	Qty	1											
250mL Plastic HNO3	1												
DS													
-07	Kit 2 Bay Single Sink (6)	6/17	4:09 AM	Grab	DW	ICP-MS Lead							
							<table border="1"><tr><td>Container</td><td>Qty</td><td>1</td></tr><tr><td>250mL Plastic HNO3</td><td>1</td><td></td></tr></table>	Container	Qty	1	250mL Plastic HNO3	1	
Container	Qty	1											
250mL Plastic HNO3	1												
DS													
-08	Kit Prep Sink (7)	6/17	4:12 AM	Grab	DW	ICP-MS Lead							
							<table border="1"><tr><td>Container</td><td>Qty</td><td>1</td></tr><tr><td>250mL Plastic HNO3</td><td>1</td><td></td></tr></table>	Container	Qty	1	250mL Plastic HNO3	1	
Container	Qty	1											
250mL Plastic HNO3	1												
DS													

Released By <u>Samantha Patrick</u>	Date / Time <u>6/17/25 7:30 AM</u>	Received By <u>Don D Pace</u>	Date / Time <u>6/18/25 1220</u>
Released By <u>Don D Pace</u>	Date / Time <u>6/18/25 1520</u>	Received By <u>P. Dely</u>	Date / Time <u>6/19/25 11:23 4-6</u>





Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Page 3 of 13

Lab ID	Sample Source: Field ID	Sampled Date Time	SampleType	Matrix	Analysis Requested	Field Analysis	Time	Measurement
-09	Kit 3 Bar Right Sink (8) BAY	6/17 4:23 AM	Grab	DW	ICP-MS Lead			
DS						Container	Qty	1
						250mL Plastic HNO3	1	
-10	Kit 3 Bay Left Sink (9)	6/17 4:27 AM	Grab	DW	ICP-MS Lead			
DS						Container	Qty	1
						250mL Plastic HNO3	1	
-11	Kit Single Middle Sink (10)	6/17 4:30 AM	Grab	DW	ICP-MS Lead			
DS						Container	Qty	1
						250mL Plastic HNO3	1	
-12	Kit 2 Bay by office sink (11)	6/17 4:35 AM	Grab	DW	ICP-MS Lead			
DS						Container	Qty	1
						250mL Plastic HNO3	1	
-13	Faulty Room Sink (12)	6/17 4:39 AM	Grab	DW	ICP-MS Lead			
DS						Container	Qty	1
						250mL Plastic HNO3	1	

Released By

Damian Fitzpatrick

Date / Time

6/17/25 7:30 AM

Received By

Don D Pace

Date / Time

6/18/25 1220

Released By

Don D Pace

Date / Time

6/18/25 1520

Received By

P.D. App

Date / Time

6/19/25 11:23 4.6

Page 3 of 13

Page 39 of 54



Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Page 4 of 13

Lab ID	Sample Source: Field ID	Sampled		Sample Type	Matrix	Analysis Requested		
		Date	Time				Field Analysis	Time
-14	Rm C-8 Fountain (13)	6/17	4:45 AM	Grab	DW	ICP-MS Lead		
DS								
	<del>Boys Locker Right Fountain (14)</del>			Grab	DW	ICP-MS Lead		
DS								
	<del>Boys Locker Left Fountain (15)</del>			Grab	DW	ICP-MS Lead		
DS								
	<del>Girls Locker Right Fountain (16)</del>			Grab	DW	ICP-MS Lead		
DS								
	<del>Girls Locker Left Fountain (17)</del>			Grab	DW	ICP-MS Lead		
DS								

Container	Qty	1
250mL Plastic HNO3	1	

Container	Qty	1
250mL Plastic HNO3	1	

Container	Qty	1
250mL Plastic HNO3	1	

Container	Qty	1
250mL Plastic HNO3	1	

Released By

*Damian Fitzpatrick*

Date / Time

6/17/25 7:30 AM

Received By

*Don D Pace*

Date / Time

6/18/25 1220

Released By

*Don D Pace*

Date / Time

6/18/25 1520

Received By

*PD*

Date / Time

6/19/25 11:23 4.6





Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Page 5 of 13

Lab ID	Sample Source: Field ID	Sampled Date Time	Sample Type	Matrix	Analysis Requested	Field Analysis	Time	Measurement
	<del>Girls Locker Back Fountain (18)</del>		Grab	DW	ICP-MS Lead			
						Container	Qty	1
						250mL Plastic HNO3	1	
DS								
-15	Nurses Office Sink (19) 14	6/17 4:54 AM	Grab	DW	ICP-MS Lead			
						Container	Qty	1
						250mL Plastic HNO3	1	
DS								
-16	Business Wing Bottle Fill (20) 15	6/17 4:59 AM	Grab	DW	ICP-MS Lead			
						Container	Qty	1
						250mL Plastic HNO3	1	
DS								
-17	Business Wing Fountain (21) 16	6/17 5:01 AM	Grab	DW	ICP-MS Lead			
						Container	Qty	1
						250mL Plastic HNO3	1	
DS								
-18	Rm. 100 Sink (22) 17	6/17 5:05 AM	Grab	DW	ICP-MS Lead			
						Container	Qty	1
						250mL Plastic HNO3	1	
DS								

Released By

*Liam Fitzpatrick*

Date / Time

*6/17/25 7:30 AM*

Received By

*Don D Pace*

Date / Time

*6/18/25 1220*

Released By

*Don D Pace*

Date / Time

*6/18/25 1522*

Received By

*P. D. D.*

Date / Time

*6/19/25 11:23 46*

Page 5 of 13

Page 41 of 54



Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Page 6 of 13

Lab ID	Sample Source: Field ID	Sampled		Sample Type	Matrix	Analysis Requested	Field Analysis	Time	Measurement				
		Date	Time										
-19	Rm. 142 Home Ec Sink (23) G-10 18	6/17	5:11 AM	Grab	DW	ICP-MS Lead							
DS													
<table border="1"><thead><tr><th>Container</th><th>Qty</th></tr></thead><tbody><tr><td>250mL Plastic HNO3</td><td>1</td></tr></tbody></table>										Container	Qty	250mL Plastic HNO3	1
Container	Qty												
250mL Plastic HNO3	1												
-20	Rm. 142 Home EC Sink (24) G-11 19	6/17	5:15 AM	Grab	DW	ICP-MS Lead							
DS													
<table border="1"><thead><tr><th>Container</th><th>Qty</th></tr></thead><tbody><tr><td>250mL Plastic HNO3</td><td>1</td></tr></tbody></table>										Container	Qty	250mL Plastic HNO3	1
Container	Qty												
250mL Plastic HNO3	1												
-21	Rm. 142 Home Ec Sink (25) G-12 20	6/17	5:19 AM	Grab	DW	ICP-MS Lead							
DS													
<table border="1"><thead><tr><th>Container</th><th>Qty</th></tr></thead><tbody><tr><td>250mL Plastic HNO3</td><td>1</td></tr></tbody></table>										Container	Qty	250mL Plastic HNO3	1
Container	Qty												
250mL Plastic HNO3	1												
-22	Rm. 142 Home Ec Sink (26) G-13 21	6/17	5:22 AM	Grab	DW	ICP-MS Lead							
DS													
<table border="1"><thead><tr><th>Container</th><th>Qty</th></tr></thead><tbody><tr><td>250mL Plastic HNO3</td><td>1</td></tr></tbody></table>										Container	Qty	250mL Plastic HNO3	1
Container	Qty												
250mL Plastic HNO3	1												
-23	Rm. 142 Home Ec Sink (27) G-14 22	6/17	5:26 AM	Grab	DW	ICP-MS Lead							
DS													
<table border="1"><thead><tr><th>Container</th><th>Qty</th></tr></thead><tbody><tr><td>250mL Plastic HNO3</td><td>1</td></tr></tbody></table>										Container	Qty	250mL Plastic HNO3	1
Container	Qty												
250mL Plastic HNO3	1												

Released By

*Damian Fitzpatrick*

Date / Time

6/17/25 7:30 AM

Received By

*Don D Pace*

Date / Time

6/18/25 12:20

Released By

*Don D Pace*

Date / Time

6/18/25 1:52

Received By

*P. Delfino*

Date / Time

6/19/25 11:23 4.6





Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Page 7 of 13

Lab ID	Sample Source: Field ID	Sampled		Sample Type	Matrix	Analysis Requested	Field Analysis	
		Date	Time				Time	Measurement
-24	Rm. 142 Home Ec Sink (28) 6-15 23	6/17	5:29 AM	Grab	DW	ICP-MS Lead		
DS								
							Container	Qty 1
							250mL Plastic HNO3	1
-25	Auditorium left bottle fill (29) 24	6/17	5:33 AM	Grab	DW	ICP-MS Lead		
DS								
							Container	Qty 1
							250mL Plastic HNO3	1
-26	Auditorium right bottle fill (30) 25	6/17	5:36 AM	Grab	DW	ICP-MS Lead		
DS								
							Container	Qty 1
							250mL Plastic HNO3	1
-27	English Wing Bottle Fill (31) 26	6/17	5:39 AM	Grab	DW	ICP-MS Lead		
DS								
							Container	Qty 1
							250mL Plastic HNO3	1
-28	Rm. 137 Sink (32) 27	6/17	5:41 AM	Grab	DW	ICP-MS Lead		
DS								
							Container	Qty 1
							250mL Plastic HNO3	1

Released By Samantitzpatrick Date / Time 6/17/25 7:30 AM Received By Don D Pace Date / Time 6/18/25 12:20  
Released By Don D Pace Date / Time 6/18/25 1:50 Received By P. Dotz Date / Time 6/19/25 11:23 4:6



Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Page 8 of 13

Lab ID	Sample Source: Field ID	Sampled		Sample Type	Matrix	Analysis Requested	Field Analysis		
		Date	Time				Time	Measurement	
-29	Science Wing Bottle Fill (33) 28	6/17	5:51 AM	Grab	DW	ICP-MS Lead			
DS									
							Container	Qty	1
							250mL Plastic HNO3	1	
-30	Science Wing Fountain (34) 29	6/17	5:53 AM	Grab	DW	ICP-MS Lead			
DS									
							Container	Qty	1
							250mL Plastic HNO3	1	
-31	Math Wing Bottle Fill (35) 30	6/17	6:00 AM	Grab	DW	ICP-MS Lead			
DS									
							Container	Qty	1
							250mL Plastic HNO3	1	
-32	Math Wing Fountain (36) 31	6/17	6:02 AM	Grab	DW	ICP-MS Lead			
DS									
							Container	Qty	1
							250mL Plastic HNO3	1	
-33	Upper Library Ofc Sink (37) 32	6/17	6:11 AM	Grab	DW	ICP-MS Lead			
DS									
							Container	Qty	1
							250mL Plastic HNO3	1	

Released By Dominic Fitzpatrick

Date / Time 6/17/25 7:30 AM

Received By Don D Pace

Date / Time 6/18/25 1220

Released By Don D Pace

Date / Time 6/18/25 1520

Received By P. Dady

Date / Time 6/19/25 11:23 4.6





Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Page 1 of 13

Client: West Milford BOE

46 Highlander Drive West Milford, NJ 07480

Project: West Milford High School: WM HS - DOE Lead 1st Draw + Flush

Project Mgr: Laura Tallia

(p) 973-697-1700, (c)

Project #: WM High School

PO #:

Comments:

\*\*1st Draw - Water Stagnation min. 8 hrs\*\*

16 Nosenzo Pond Rd, West Milford, NJ 07480

### Turn Around Time

☐ Standard 2 Weeks

### Rush (Choose One Below) \*\*

☐ 24 Hr. ☐ 72 Hr.

☐ 48 Hr. ☐ 1 Week

☐ Other (provide Date/Time)

Date: \_\_\_\_\_ Time: \_\_\_\_\_

\*\* May Need Lab Approval

### Report / Electronic Format

☐ Results Only/Lvl 2

☐ Email Delivery

☐ NJ DEP Reduced

☐ Hazsite EDD

☐ NJ DEP Full

☐ EQUIS EDD

☐ State Forms/E2

☐ Excel

PWSID # 1615326

SRP # \_\_\_\_\_

Lab ID	Sample Source: Field ID	Sampled Date Time	Sample Type	Matrix	Analysis Requested	Field Analysis	Time	Measurement
	Field Blank		Field Blank	DW	ICP-MS Lead			
						Container	Qty	1
						250mL Plastic HNO3	1	
34	Loading Dock Hose Bib (1)	6-17-25 3:44 AM	Grab	DW	ICP-MS Lead			
	Flushed					Container	Qty	1
						250mL Plastic HNO3	1	
DS								
	Loading Dock right ice machine (2)	6-17-25 3:57 AM	Grab	DW	ICP-MS Lead			
	Flushed					Container	Qty	1
						250mL Plastic HNO3	1	
DS								

Released By

Lamar Fitzpatrick

Date / Time

6/17/25 2:30 AM

Received By

Don D Pace

Date / Time

6/18/25 1220

Released By

Don D Pace

Date / Time

6/18/25 1528

Received By

P.D. Dady

Date / Time

6/19/25 11:20 4.6

Page X of 13

Page 45 of 54



Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Page 2 of 13

Lab ID	Sample Source: Field ID	Sampled		Sample Type	Matrix	Analysis Requested	Field Analysis		
		Date	Time				Time	Measurement	
-35	Loading Dock left Ice Machine (3) Flushed	6/17	3:57 AM	Grab	DW	ICP-MS Lead			
DS									
							Container	Qty	1
							250mL Plastic HNO3	1	
-36	Boys Locker Rm. Hallway Left Bottle Fill (4) Flushed	6/17	6:47 AM	Grab	DW	ICP-MS Lead			
DS									
							Container	Qty	1
							250mL Plastic HNO3	1	
<del>36</del> 37	Boys locker rm. Hallway right bottle fill (5) Flushed	6/17	6:45 AM	Grab	DW	ICP-MS Lead			
DS									
							Container	Qty	1
							250mL Plastic HNO3	1	
<del>37</del> 38	Kit 2 Bay Single Sink (6) Flushed	6/17	4:10 AM	Grab	DW	ICP-MS Lead			
DS									
							Container	Qty	1
							250mL Plastic HNO3	1	
<del>38</del> 39	Kit Prep Sink (7) Flushed	6/17	4:13 AM	Grab	DW	ICP-MS Lead			
DS									
							Container	Qty	1
							250mL Plastic HNO3	1	

Released By Samuel Fitzpatrick Date / Time 6/17/25 7:30 AM Received By Don D Pace Date / Time 6/18/25 1220  
Released By Don D Pace Date / Time 6/18/25 1524 Received By P. D. Ayers Date / Time 6/19/25 11:23 46





Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Page 3 of 13

Lab ID	Sample Source: Field ID	Sampled		Sample Type	Matrix	Analysis Requested	Field Analysis		
		Date	Time				Time	Measurement	
<del>40</del> 40	Kit 3 Bar Right Sink (8) Bay Flushed	6/17	4:25 AM	Grab	DW	ICP-MS Lead	Container	Qty	1
							250mL Plastic HNO3	1	
DS									
<del>41</del> 41	Kit 3 Bay Left Sink (9) Flushed	6/17	4:27 AM	Grab	DW	ICP-MS Lead	Container	Qty	1
							250mL Plastic HNO3	1	
DS									
<del>42</del> 42	Kit Single Middle Sink (10) Flushed	6/17	4:32 PM	Grab	DW	ICP-MS Lead	Container	Qty	1
							250mL Plastic HNO3	1	
DS									
<del>43</del> 43	Kit 2 Bay by office sink (11) Flushed	6/17	4:32 PM	Grab	DW	ICP-MS Lead	Container	Qty	1
							250mL Plastic HNO3	1	
DS									
<del>44</del> 44	Faulty Room Sink (12) Flushed	6/17	4:41 PM	Grab	DW	ICP-MS Lead	Container	Qty	1
							250mL Plastic HNO3	1	
DS									

Released By	<i>Damian Fitzpatrick</i>	Date / Time	6/17/25 7:30 PM	Received By	<i>Don D Pace</i>	Date / Time	6/18/25 12:00
Released By	<i>Don D Pace</i>	Date / Time	6/18/25 15:00	Received By	<i>P. Doty</i>	Date / Time	6/19/25 11:23 4:6

Page 3 of 13

Page 47 of 54



Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Lab ID	Sample Source: Field ID	Sampled		Sample Type	Matrix	Analysis Requested	Field Analysis		
		Date	Time				Time	Measurement	
45	Rm C-8 Fountain (13) Flushed	6/17	4:49 AM	Grab	DW	ICP-MS Lead			
DS							Container	Qty	1
							250mL Plastic HNO3	1	
	<del>Boys Locker Right Fountain (14)</del>			Grab	DW	ICP-MS Lead			
DS							Container	Qty	1
							250mL Plastic HNO3	1	
	<del>Boys Locker Left Fountain (15)</del>			Grab	DW	ICP-MS Lead			
DS							Container	Qty	1
							250mL Plastic HNO3	1	
	<del>Girls Locker Right Fountain (16)</del>			Grab	DW	ICP-MS Lead			
DS							Container	Qty	1
							250mL Plastic HNO3	1	
	<del>Girls Locker Left Fountain (17)</del>			Grab	DW	ICP-MS Lead			
DS							Container	Qty	1
							250mL Plastic HNO3	1	

Released By	<i>Damian Fitzpatrick</i>	Date / Time	<i>6/17/25 7:30 AM</i>	Received By	<i>Don D Pace</i>	Date / Time	<i>6/18/25 1220</i>
Released By	<i>Don D Pace</i>	Date / Time	<i>6/18/25 1520</i>	Received By	<i>P. Dufay</i>	Date / Time	<i>6/19/25 11:28 4.6</i>





Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Page 5 of 13

Lab ID	Sample Source: Field ID	Sampled Date Time	Sample Type	Matrix	Analysis Requested	Field Analysis	Time	Measurement
	<del>Girls Locker Back Fountain (18)</del>		Grab	DW	ICP-MS Lead			
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	
-46	Nurses Office Sink (19) Flushed 14	6/17 4:56 AM	Grab	DW	ICP-MS Lead			
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	
-47	Business Wing Bottle Fill (20) Flushed 15	6/17 6:49 AM	Grab	DW	ICP-MS Lead			
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	
-48	Business Wing Fountain (21) Flushed 16	6/17 5:03 AM	Grab	DW	ICP-MS Lead			
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	
-49	Rm. 100 Sink (22) Flushed 17	6/17 5:07 AM	Grab	DW	ICP-MS Lead			
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	

Released By

*Damian Fitzpatrick*

Date / Time

6/17/25 7:30 AM

Received By

*Don D Pace*

Date / Time

6/18/25 1220

Released By

*Don D Pace*

Date / Time

6/18/25 1520

Received By

*P.D. Ayer*

Date / Time

6/19/25 11:23 4.6

Page 5 of 13

Page 49 of 54



Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Page 6 of 13

Lab ID	Sample Source: Field ID	Sampled Date Time	Sample Type	Matrix	Analysis Requested	Field Analysis	Time	Measurement
-50	Rm. 142 Home Ec Sink (23) G-10 Flushed 18	6/17 5:13 AM	Grab	DW	ICP-MS Lead			
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	
-51	Rm. 142 Home EC Sink (24) G-11 Flushed 19	6/17 5:17 AM	Grab	DW	ICP-MS Lead			
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	
-52	Rm. 142 Home Ec Sink (25) G-12 Flushed 20	6/17 5:21 AM	Grab	DW	ICP-MS Lead			
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	
-53	Rm. 142 Home Ec Sink (26) G-13 Flushed 21	6/17 5:24 AM	Grab	DW	ICP-MS Lead			
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	
-54	Rm. 142 Home Ec Sink (27) G-14 Flushed 22	6/17 5:28 AM	Grab	DW	ICP-MS Lead			
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	

Released By Damian Fitzpatrick Date / Time 6/17/25 7:30 AM Received By Don D Pace Date / Time 6/18/25 12:20  
Released By Don D Pace Date / Time 6/18/25 15:20 Received By P. Dady Date / Time 6/19/25 11:23 4.6

Page 6 of 13

Page 50 of 54





Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Page 7 of 13

Lab ID	Sample Source: Field ID	Sampled Date Time	Sample Type	Matrix	Analysis Requested	Field Analysis	Time	Measurement
-55	Rm. 142 Home Ec Sink (28) 6-15 Flushed 23	6/17 5:31 AM	Grab	DW	ICP-MS Lead			
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	
SAMPLE #	Auditorium left bottle fill (29)	6/17 7:00 AM	Grab	DW	ICP-MS Lead			
25F 2124-65	Flushed 24							
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	
-56	Auditorium right bottle fill (30) Flushed 25	6/17 6:56 AM	Grab	DW	ICP-MS Lead			
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	
-57	English Wing Bottle Fill (31) Flushed 26	6/17 6:53 AM	Grab	DW	ICP-MS Lead			
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	
-58	Rm. 137 Sink (32) Flushed 27	6/17 5:43 AM	Grab	DW	ICP-MS Lead			
DS								
						Container	Qty	1
						250mL Plastic HNO3	1	

Released By Damian Fitzpatrick

Date / Time 6/17/25 7:30 AM

Received By Don D Pace

Date / Time 6/18/25 12:20

Released By Don D Pace

Date / Time 6/18/25 15:24

Received By P. Deby

Date / Time 6/19/25 11:23 4.6



Pace Analytical Services, LLC Fairfield NJ  
1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422

## CHAIN OF CUSTODY

Page 8 of 13

Lab ID	Sample Source: Field ID	Sampled Date Time	Sample Type	Matrix	Analysis Requested	Field Analysis	Time	Measurement
<del>58</del> 59	Science Wing Bottle Fill (33)	6/17 6:10 AM	Grab	DW	ICP-MS Lead			
DS	Flushed 28							
						Container	Qty	1
						250mL Plastic HNO3	1	
<del>59</del> 60	Science Wing Fountain (34)	6/17 5:55 AM	Grab	DW	ICP-MS Lead			
DS	Flushed 29							
						Container	Qty	1
						250mL Plastic HNO3	1	
<del>60</del> 61	Math Wing Bottle Fill (35)	6/17 6:16 AM	Grab	DW	ICP-MS Lead			
DS	Flushed 30							
						Container	Qty	1
						250mL Plastic HNO3	1	
<del>61</del> 62	Math Wing Fountain (36)	6/17 6:55 AM	Grab	DW	ICP-MS Lead			
DS	Plushed 31							
						Container	Qty	1
						250mL Plastic HNO3	1	
<del>62</del> 63	Upper Library Ofc Sink (37)	6/17 6:13 AM	Grab	DW	ICP-MS Lead			
DS	Flushed 32							
						Container	Qty	1
						250mL Plastic HNO3	1	

Released By <u>Damian Fitzpatrick</u>	Date / Time <u>6/17/25 7:30 AM</u>	Received By <u>Don D Pace</u>	Date / Time <u>6/18/25 1220</u>
Released By <u>Don D Pace</u>	Date / Time <u>6/18/25 1520</u>	Received By <u>P. Dudge</u>	Date / Time <u>6/19/25 11:23 4.6</u>

Page 8 of 13

Page 52 of 54



**Pace® Analytical Laboratory**  
**1275 Bloomfield Ave., Bldg. 6, Fairfield, New Jersey**  
**07004**  
**973.227.0422 | [pacelabs.com](http://pacelabs.com)**

**Instructions for Drinking Water Lead and Copper Testing**

Dear Water Customer:

Thank you for contacting us regarding Lead and/or Copper testing for your water. In order to sample your system for lead and/or copper contamination, we need to have you collect water samples drawn first thing in the morning, before any general water use in the water system. We appreciate your cooperation in this. A pickup date for the sample along with the bottom of this sheet should be arranged at the time of instruction and bottle drop off.

With this sheet, bottles were dropped off for sampling use. Please read the following instructions carefully. A sample is to be collected after an extended period of time (6-12 hours) with no water use during this time period within the interior piping.


The following is the proper sampling protocol:

1. Wait a minimum of eight (8) hours, but not more than eighteen (18) hours with no water being used during this time. (Example: Go to bed at 11 p.m., wake up at 7 a.m. and collect before any water usage).
2. You have been provided a one (1) liter bottle specially prepared for this analysis by PACE, use this bottle only for this purpose. **DO NOT RINSE BOTTLE!**
3. A kitchen or bathroom COLD water faucet is to be used for sampling. Place the bottle under the tap and slowly fill the bottle to the shoulder and turn water off.
4. Tightly cap the bottle and fill out the label to the best of your ability. In addition, please fill out the information provided below.
5. Leave the bottle outside on the arranged date for pick up to be brought back to the Laboratory for analysis.
6. Mark each bottle with the sample location, date and time of sampling.

THANK YOU FOR YOUR COOPERATION!

Water was last used      Time: 8:00PM      Date: 6-16-25

I have read the above directions and have taken a sample in accordance with this sample protocol:

Signature:   
Name: Damian Fitzpatrick      973      Phone# 697-1700  
Address: 67 Highlander Drive West Milford New Jersey

Sample Condition Upon Receipt Form (SCUR)



Affix Samp25F2124

Date and Initials of person:  
Examining contents: \_\_\_\_\_  
Label: \_\_\_\_\_  
Deliver to location: \_\_\_\_\_  
pH: \_\_\_\_\_

Thermometer Used: 11TR05 Date: 6/10/15 Time: 11:27 Initials: PAD  
State of Origin: NJ

Cooler #1 Temp: °C 4.6 (Visual) 0 (Correction Factor) 4.6 (Actual)

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace  
Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground  
☐ Other \_\_\_\_\_

Tracking # \_\_\_\_\_

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals Intact: ☐ Yes ☐ No Ice: Wet ☒ Blue ☐ Melted ☐ None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other \_\_\_\_\_  
Samples were collected by Pace employee ☒ Yes ☐ No ☐ N/A

	Yes	No	N/A	Comments:
Chain of Custody Present	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Chain of Custody Filled Out	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Relinquished Signature on COC	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Sampler Name and Signature on COC	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Samples Arrived within Hold Time	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Rush TAT requested on COC	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Sufficient Volume	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Correct Containers Used	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Containers Intact	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Sample Labels match COC (sample IDs & date/time of collection)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Some <del>boxes</del> /SAMPLE IDs were not identical ON SAMPLES TO LABEL
All containers needing acid/base preservation have been checked.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lot #/Trace #: _____
Exceptions: Vials, Microbiology, O&G, Metals				Date: _____ Time: _____
Headspace in VOA Vials? (>6mm):	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Initials: _____
Trip Blank Present:	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

Additional Login Comments:

Client notification/ Resolution

Person Contacted:

Date/Time:

Comments/Resolution: