



Passaic Valley Water Commission
1525 Main Avenue • P.O. Box 230
Clifton, NJ 07011

High Crest PWSID NJ 1615003

PASSAIC VALLEY WATER COMMISSION

2025 Drinking Water Quality Report

Based on Data from the 2024 Calendar Year

HC

Date: 4/22/2025

Dear Passaic Valley Water Commission Consumers,

I trust this message reaches you in good spirits. As we look back on the past year, I am excited to present the 2025 Annual Consumer Confidence Report (CCR) containing 2024 Drinking Water Quality Report. This report underscores our dedication to ensuring that you have access to safe and dependable drinking water as we uphold our responsibilities as public stewards of health, community welfare, and economic development for both current and future generations.

In 2024, the Passaic Valley Water Commission (PVWC) maintained compliance with all standards set by the New Jersey Department of Environmental Protection (NJDEP) and the United States Environmental Protection Agency (EPA). Our committed team consistently strives to ensure that your water is treated and delivered with exceptional care and precision.

PVWC consistently collects water samples from over 100 distinct locations each week, with certain sites having multiple samples. The frequency of collection varies, occurring monthly, quarterly, or annually based on seasonal requirements. On average, PVWC analyzes more than 1,000 samples each month. During this comprehensive monitoring, the organization tests for over 200 regulated and unregulated contaminants, ensuring that the drinking water supplied meets or exceeds both state and federal quality standards.

Here are a few key points of the CCR:

- Microbiological Contaminants - No *E. coli* was detected.
- Lead and Copper: Regulated at the consumer tap (12 homes), Not exceeding the Action Level.
- Disinfection Byproduct (DBP): DBPs are formed when disinfectants like chlorine interact with natural organic materials in water, such as in chlorinated drinking water and chlorine-treated swimming pools. The most common type of DBPs are Trihalomethanes (TTHM).
 - TTHM: The test results show that the annual average is below the set threshold of 80 parts per billion (ppb) for the Maximum Contaminant Level.
- Disinfection Residual: Maintaining disinfectant residuals in the water distribution system is crucial for ensuring safe and clean drinking water.
 - Chlorine acts as a disinfectant residual to inactivate bacteria and some viruses that cause diarrheal disease. The highest running annual average falls below the established threshold of 4 parts per million (ppm).
- Source Water Pathogen Monitoring:
 - *Cryptosporidium*, a microbial pathogen commonly present in surface water throughout the United States of America and is mostly non-detected in our water system.
 - Table of Detected Contaminants: There have been no violations, and all the results obtained are below the Maximum Contaminant Level.
- Table of Detected Secondary Parameter: Secondary contaminants may not be health-threatening, but they can affect water aesthetics which include undesirable taste and odor, and cosmetic effects include skin or tooth discoloration.


PVWC will continue to provide you with timely and relevant information about your water quality and any potential concerns.

In 2024, High Crest reported no violations from NJDEP regarding water quality parameters.

For any inquiries regarding this report on water quality, water pressure, billing, construction projects, or other matters, please reach out to our customer service department at 973-340-4300. Our operating hours, including the walk-up payment window, are Monday through Friday, excluding State holidays, from 7:30 a.m. to 6:00 p.m. Our phone lines are available until 6:30 p.m. You may also contact us via email at customerservice@pvwc.com. For further information about PVWC, including important updates and alerts, please visit <https://www.pvwc.com>. Emergency services are accessible 24/7 by calling 973-340-4300.

We appreciate your ongoing trust and support. It is our privilege to serve you, and we are dedicated to delivering safe, dependable, and high-quality drinking water.

Sincerely,


James Mueller
Executive Director

This report covers water quality for the High Crest Service Area in West Milford.

If your home or business is located in the High Crest Area of West Milford you are in PVWC's High Crest Service Area. PVWC is a public drinking water supplier owned by the cities of Paterson, Clifton, and Passaic.

Source Water and Treatment

PVWC purchases treated water from the Borough of Butler for distribution to the High Crest Community. Butler obtains their water from the 150-acre Kikeout Reservoir and treats it at the Butler WTP. Butler's treatment includes a conventional 4.0-million gallons per day system with polyaluminum chloride (PACl) and/or alum coagulation, pulsator clarification, and pressure filtration. Following clarification, sodium hydroxide is applied to the water to adjust the pH. Chlorine is then added to the treated water prior to the pressure filters. Orthophosphate is added to the filtered water for corrosion control, followed by chlorine before distribution. PVWC further adds chlorine immediately prior to the High Crest system to maintain a disinfectant residual in the distribution system.

Source Water Assessment

The New Jersey Department of Environmental Protection (NJDEP) has prepared Source Water Assessment reports and summaries for all public water systems. The Source Water Assessment for the Butler Water System (PWS ID 1403001) can be obtained by accessing NJDEP's source water assessment website at <http://www.nj.gov/dep/watersupply/swap/index.html> or by contacting NJDEP's Bureau of Safe Drinking Water at 609-292-5550 or watersupply@dep.nj.gov. If a system is rated highly susceptible for a contamination category, it does not mean a customer is or will be consuming contaminated water. The rating reflects the potential for contamination of a source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any of those contaminants are detected at frequencies and concentrations above allowable levels. The source water assessments performed on Butler's Kakeout Reservoir intake lists the following susceptibility ratings for a variety of contaminants that may present in source waters:

Intake Susceptibility Ratings

Sources	Pathogens	Nutrients	Pesticides	Volatile Organic Compounds	Inorganic Contaminants	Radionuclides	Radon	Disinfection Byproduct Precursors
Butler Water System 1 -Surface Water Intake	High	Low	Low	Medium	Medium	Low	Low	High

Susceptibility
Chart Definitions

Pathogens: Disease-causing organisms such as bacteria, protozoa, and viruses, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife. Common sources are animal and human fecal wastes. These contaminants may be present in source water.

Nutrients: Compounds, minerals and elements that aid growth, which can be either naturally occurring or man-made. Examples include nitrogen and phosphorus.

Pesticides: Man-made chemicals used to control pests, weeds, and fungus. Common sources include manufacturing centers of pesticides, and where they are used in agricultural, industrial, commercial, and residential environments. Examples include herbicides such as atrazine, and insecticides such as chlordane.

Volatile Organic Compounds: Compounds containing carbon, including synthetic and volatile organic chemicals, which are products or by-products of industrial processes or petroleum production. They are typically used as solvents, degreasers, and gasoline components. These compounds may be present in source water as a result of releases from gas stations, fuel storage tanks, industrial facilities, stormwater runoff, and other sources. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

Inorganic Contaminants: Contaminants such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming. These contaminants may be present in source water.

Radionuclides: Radioactive substances that are both naturally occurring and man-made; may be present in source water naturally or as a result of oil and gas production and mining activities. Examples include radium, radon and uranium.

Radon: Colorless, odorless, cancer-causing gas that occurs naturally in the environment.

Disinfection By-product Precursors: A common source is naturally-occurring organic material in surface water. Disinfection by-products are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (DBP precursors) present in surface water.

About This Report

In order to ensure that tap water is safe to drink, the Environmental Protection Agency (EPA) prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health. The NJ Department of Environmental Protection is charged with monitoring compliance with those limits by water providers in the state.

All drinking water, including bottled water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. For more information about contaminants and potential health effects call the EPA's Safe Drinking Water Hotline at 800-426-4791 or visit www.epa.gov/safewater.

The sources of drinking water, both tap and bottled, include surface sources such as rivers, streams, lakes, reservoirs and groundwater sources (wells). As water moves through the ground or over surfaces it dissolves naturally occurring minerals and in some cases, radioactive material. Water can also pick up substances resulting from the presence of human or animal activity. Contaminants that may be present in the source water include:


Microbial contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, pet waste and wildlife.

Inorganic contaminants - such as salts and metals, which can occur naturally or result from urban storm runoff industrial or domestic wastewater discharges, oil and gas productions, mining or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, stormwater runoff, and residential uses.

Organic Chemical contaminants, including both synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas production, urban stormwater runoff and septic systems.

Radioactive contaminants - which can be naturally occurring or can be the result of oil and gas production and mining activities.



Definitions

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Haloacetic Acids (HAAs): By-products of the treatment process that are formed when the disinfectant chlorine combines with organic matter in the source water. Since chlorine is important for disinfection, HAAs will be present, but they are monitored very closely by water utilities.

Parts Per Million (ppm) or Milligrams Per Liter (mg/L): A measure of the concentration of a substance in a given volume of water. One part per million corresponds to one penny in \$10,000.

Parts Per Billion (ppb) or Micrograms Per Liter (ug/L): An even finer measure of concentration. One part per billion corresponds to one penny in \$10,000,000.

Parts Per Trillion (ppt) or nanograms Per Liter (ng/L): An even finer measure of concentration. One part per trillion corresponds to one penny in \$100,000,000.

Picocuries Per Liter (pCi/L): A measure of radioactivity.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible, using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Nephelometric Turbidity Units (ntu): A measure of particles in water.


Recommended Upper Limit (RUL): The highest level of a constituent of drinking water that is recommended in order to protect aesthetic quality.

Total Trihalomethanes (TTHMs): By-products of the treatment process that are formed when the disinfectant chlorine combines with organic matter in the source water. Since chlorine is important for disinfection, TTHMs will be present, but they are monitored very closely by water utilities.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

SPECIAL CONSIDERATIONS REGARDING CHILDREN, PREGNANT WOMEN, NURSING MOTHERS AND OTHERS

Children may receive a slightly higher amount of a contaminant present in the water than do adults, on a body weight basis, because they may drink a greater amount of water per pound of body weight than do adults. For this reason, reproductive or developmental effects are used for calculating a drinking water standard if these effects occur at lower levels than other health effects of concern. If there is insufficient toxicity information for a chemical (for example, lack of data on reproductive or developmental effects), an extra uncertainty factor may be incorporated into the calculation of the drinking water standard, thus making the standard more stringent, to account for additional uncertainties regarding these effects. In the cases of lead and nitrate, effects on infants and children are the health endpoints upon which the standards are based.



A Note to People with Special Health Concerns

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to reduce the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 800-426-4791.

2024 Water Quality Results -- Table of Detected Contaminants

High Crest PWSID: NJ1615003

Regulated Contaminant (units)	Goal (MCLG)	Highest Level Allowed (MCL)	Butler WTP PWSID: NJ1403001	Source of Substance	Violation
Treated Drinking Water at Treatment Plant					
Turbidity (NTU)	N/A	Treatment Technique (TT) =1	Highest Level Detected 5.21 NTU	Soil run-off	No
	N/A	TT = % of samples <0.3 NTU (min 95%)	Lowest Monthly % of Samples meeting Turbidity Limits = 99.89%		
Turbidity is a measure of the cloudiness of the water and is monitored as an indicator of water quality. High turbidity can limit the effectiveness of disinfectants.					
Total Organic Carbon (%)	N/A	TT = % Removal or Removal Ratio	1.35 (Running Annual Average) 48 - 66.67 (actual range of % removal) % removal required - 35 - 45%	Naturally present in the environment	No
Inorganic Contaminants					
Barium (ppm)	2	2	0.006	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	No
Chromium (ppb)	100	100	0.466	Discharge from steel & pulp mills	No
Nickel (ppb)	N/A	N/A	0.468	Erosion of Natural Deposits	No
Radiological Contaminants - 2024 Data					
Gross Alpha (pCi/L)	0	15	1.22	Erosion of Natural Deposits	No
Combined Radium (pCi/L)	0	5	0.33	Erosion of Natural Deposits	No
Perfluorinted Compound					
			Range (ppt)		
Perfluorooctanesulfonic acid (PFOS) (ppt)	0	13 ¹	3.16 (Highest detected level)	Discharge from manufacturing and industrial chemical facilities, use of certain consumer products, occupational exposures and certain firefighting activities.	No
Perfluorooctanoic acid (PFOA) (ppt)	0	14 ¹	2.03 - 3.16 (Range)		No
¹ MCL is created by the State of New Jersey. The EPA's new regulatory threshold for PFAS, which must be included in the CCR, will take effect on April 26, 2027.					
Treated Drinking Water from Points throughout the Distribution System - High Crest PWSID NJ1615003					
Disinfectant Residual					
Chlorine (ppm)	4	4	0.79 Highest running annual average (0.43-1.03)	Water additive used to control microbes.	No
Disinfection ByProducts (DBPs)					
Haloacetic Acids [HAA5] (ppb)	N/A	60	44 Highest running annual average at any one location (26.9 - 35.5)	By-product of drinking water disinfection	No
Total Trihalomethanes [TTHM] (ppb) ²	N/A	80	475 Highest running annual average at any one location (20.3 - 35.0)	By-product of drinking water disinfection	No
² Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system and may have an increase risk of getting cancer.					
Regulated at the Consumer Tap (2024 Sampling Data)					
Copper (ppm)	1.3	1.3 (Action Level)	0.055 90th Percentile (0 out of 12 samples exceeded Action Level)	Corrosion of household plumbing systems	No
Lead (ppb)	0	15 (Action Level)	0.62 90th Percentile (0 out of 12 samples exceeded Action Level)	Corrosion of household plumbing systems	No

Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink the water over many years could develop kidney problems of high blood pressure.

NA - Not Applicable ND - Not Detected

2024 Water Quality Results -- Table of Detected Secondary Contaminants			
Contaminant (units)	NJ Recommended Upper Limit (RUL)	Butler WTP PWSID: NJ1403001	RUL Achieved
Alkalinity (ppm)	N/A	35.0 ³	N/A
Aluminum (ppb)	200	244.0 ³	No
Chloride (ppm)	250	41.1	Yes
Hardness, CaCO ₃ (ppm)	250	36.0 ³	Yes
Iron (ppb)	300	<200 ³	Yes
Manganese (ppb)	50	<40 ³	Yes
Odor (Threshold Odor Number)	3	2 ³	Yes
pH	6.5 to 8.5 (optimum range)	7.35	Yes
Sodium (ppm)	50	25.8	Yes
Sulfate (ppm)	250	5.88	Yes
Total Dissolved Solids (ppm)	500	106.0 ³	Yes

³These values from NJ Drinking Water Watch



ADDITIONAL INFORMATIONAL RESOURCES

PVWC website: www.pvwc.com
 EPA Drinking Water website: www.epa.gov/safewater
 NJDEP Water Supply website: www.nj.gov/dep/watersupply
 American Water Works Association (AWWA) website: www.awwa.org

PVWC Customer Service Department: 973-340-4300
 EPA Safe Drinking Water Hotline: 800-426-4791
 NJDEP Bureau of Safe Drinking Water: 609-292-5550
 AWWA New Jersey Section website: www.njawwa.org

Important Information About Lead In Your Drinking Water

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. PVWC is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact PVWC at 973-340-4300. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.



Health Effects of Lead

Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.

Sources of Lead

Lead is a common metal found in the environment. Drinking water is one possible source of lead exposure. The main sources of lead exposure are lead-based paint and lead-contaminated dust or soil, and some plumbing materials. Lead can also be found in certain types of pottery, pewter, brass plumbing fixtures, food, and cosmetics. Lead is found in some toys, some playground equipment, and some children's metal jewelry. Exposure in the work place and exposure from certain hobbies can also be sources (lead can be carried on clothing or shoes).

Lead is not present in the water supplied to you. When water has been in contact with pipes or plumbing that contains lead for several hours, the lead may enter the drinking water. This means the first water drawn from the tap in the morning, or later in the afternoon after returning from work or school, can contain fairly high levels of lead. Homes built before 1985 are more likely to have plumbing containing lead or lead solder. New homes may also have lead. Even brass faucets, fittings, and valves, including those advertised as "lead-free" may contain some lead.

Water Testing

Routinely, homes known to contain lead service lines and/or plumbing components are monitored in PVWC's High Crest system. These houses represent a worst-case scenario for lead in water. Samples are collected after the water has been standing in the household plumbing for 6 hours or more.

A Lead and Copper Rule exceedance for lead occurs when more than 10 percent of these homes exceed the lead action level of 15 parts per billion.

In the most recent round of testing conducted by PVWC in 2024, 0 out of 12 homes exceeded the action level for lead.

FOR MORE INFORMATION

Contact us at 973-340-4300, customerservice@pvwc.com or visit our website at www.pvwc.com. For more information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's resources below, or contact your health care provider.

EPA's Safe Drinking Water Hotline: 800-426-4791

National Lead Information Center: 800-424-LEAD

EPA Website: www.epa.gov/lead

How You Can Reduce Your Exposure to Lead

- 1. Run your water to flush out lead.** Run your cold water for 30 seconds to 2 minutes or until it becomes cold or reaches a steady temperature before using it for drinking or cooking, if it hasn't been used for several hours. This flushes lead-containing water from the pipes. Flushing usually uses less than one or two gallons of water and costs less than 30 cents per month.
- 2. Use cold water for cooking and preparing baby formula.** Do not cook with or drink water from the hot water tap; lead dissolves more easily into hot water. Do not use water from the hot water tap to make baby formula.
- 3. Do not boil water to remove lead.** Boiling water will not reduce lead.
- 4. Look for alternative sources or treatment of water.** You may want to consider purchasing bottled water or a water filter. If purchasing a water filter, read the package to be sure the filter is approved to reduce lead. You can also contact NSF International at 800-NSF-8010 or visit their website at www.nsf.org for information on performance standards for water filters. Be sure to maintain and replace a filter device in accordance with the manufacturer's instructions to protect water quality.
- 5. Test your water for lead.** Call PVWC at 973-340-4300 to find out how to get your water tested for lead, or for a list of local laboratories that are certified for testing lead. Testing is essential because you cannot see, taste, or smell lead in drinking water.
- 6. Get your child's blood tested.** Contact your local health department or healthcare provider to find out how you can get your child tested for lead if you are concerned about exposure. Your family doctor or pediatrician can perform a blood test for lead and provide you with information about the health effects of lead.
- 7. Identify and replace plumbing fixtures containing lead.** A licensed plumber can check to see if your home's plumbing contains lead solder, lead pipes, or pipe fittings that contain lead. Your local building/code department can provide you with information about building permit records that should contain the names of plumbing contractors who plumbed your home.
- 8. Find out whether your service line is made of lead.** PVWC maintains records of PVWC-owned service line materials (water main to curb box) and customer-owned service line materials (curb box to building) located in the distribution system. PVWC has prepared and submitted to NJDEP an inventory of service line materials, which is updated on an annual basis. To review your service line materials records, access the current inventory online at <https://www.pvwcleadserviceline.com/>. Or contact our Customer Service Department at 972-340-4300 for service line materials records. If the service line that comes from the curb box to your home is unknown material, you should determine whether or not the service line is made of lead. The best way to determine if the service line to your home is made of lead is by hiring a licensed plumber to inspect the line.



Passaic Valley Water Commission
1525 Main Avenue • P.O. Box 230
Clifton, NJ 07011

This report contains information about your drinking water. If you do not understand it, please have someone translate it for you.

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

આ અહેવાલ મિં તમારા પીવાના પાણી વિષે
 માહત્તી આપવા માં આવેલ છે.
 જોને અનુસાર કરો એવુ જોને સમજણ નહીં
 ત્ય તેના સાથે વાત કરો

للمعلومات في هذا التقرير تحتوي على
 معلومات مهمة عن مياه الشرب التي
 تشربها. من فضلك اذا لم تفهم هذه
 المعلومات اطلب من يترجمها لك.

Landlords must distribute this information to every tenant as soon as practicable, but no later than three business days after receipt. Delivery must be done by hand, mail or email, and by posting the information in a prominent location at the entrance of each rental premises, pursuant to section 3 of P.L. 2021, c. 82 (C.58:12A-12.4 et seq.).

Why am I getting this report?

Passaic Valley Water Commission (PVWC) is pleased to welcome you to our 2025 Water Quality Report. This report provides a summary of information collected during the calendar year 2024 regarding compliance monitoring required by both the United States Environmental Protection Agency (EPA) and the New Jersey Department of Environmental Protection (NJDEP), as well as additional water quality monitoring data. We hope that you will take a minute to review this report and learn more about your drinking water. **High Crest's water met all primary health-based standards in 2024.**

Drinking water regulations require PVWC to provide this information to customers each year. Most of the language is required by the EPA and NJDEP to make sure that our ratepayers know what is in their drinking water. PVWC has tried to make this complex information readable and produce this report at a low cost.

For additional copies of this report contact our Customer Service Department at 973-340-4300, or customerservice@pvwc.com.

We're Here for You

The PVWC Board of Commissioners encourages you to participate in decisions that may affect the quality of your drinking water. You can present your comments through the PVWC website at www.pvwc.com or come in person to the monthly meetings of the Board of Commissioners. For dates, times and locations of these meetings, or for additional copies of this report contact our Customer Service Department at 973-340-4300, or customerservice@pvwc.com. All meetings are announced in accordance with public meetings law.

For Board Agendas and Meeting Minutes, or for more information on upcoming meetings visit us at www.pvwc.com or contact our Customer Service Department at 973-340-4300, or customerservice@pvwc.com.



Commissioners

Rigo Sanchez, President, Passaic

Gerald Friend, Vice President, Clifton

Carmen DePadua, Treasurer, Paterson

Ruby N. Cotton, Secretary, Paterson

Jeffrey Levine, Commissioner, Paterson

Deborah Rizzi, Commissioner, Clifton

Ronald Van Rensalier, Commissioner, Passaic