

Doug Robinson
Superintendent

January 1, 2024

To: Grayson County Technology Center:
President of Parent Organization:


Every building owned or used by your board of education has recently been inspected for friable and nonfriable asbestos containing material. This was conducted by an inspector fully accredited by the State of Kentucky and the Environmental Protection Agency (EPA).

Your board of education has adopted a management plan for each school; these plans are located in the principal's office and may be reviewed during normal school working hours. Copies may be obtained for a small fee if prior notice is given to the office staff. A copy of this report is also available in the Superintendent's office.

Upon inspection and analysis of samples taken, it has been determined that your building contains nonfriable asbestos containing building material in the floor tiles, the mastic, and the Health Services lab table tops. This material is in good condition, is no threat to the building occupants and will be maintained properly.

Until removal, this material will be re-inspected every six months and these reports will become a part of the management plan. The district coordinator, maintenance staff and building custodians will receive sufficient training to recognize asbestos and its dangers and to respond in the proper manner.

Sincerely,



Doug Robinson, Superintendent
Grayson County Schools